

Information to be submitted by Transmission Licensee to the Commission (ATSC)

Outage details of AC Transmission Line: Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of April 2023

400KV

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	501	501	99.53	
Power Transformer/ Inter connecting Transformer (CT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Apr-23	99.766
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Apr-23	2	501

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6 % Availability Prescribed	Actual % Availability	Violation of Regulation 8 Restoration time as per Regulation (in days)	Actual Restoration time (in days)	Compensation Paid (in Rs)
NIL	NIL	NIL	NIL	NIL	NIL
Total					

*Handwritten signature and date:*  
22/12/2023

Outage details of AC Transmission Line/ Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of May-2023

(i) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	171	171	99.83	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(ii) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	May-23	99.915
HVDC Transmission System	NA	NA

(iii) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
May-23	1	171

(iv) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(v) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6	Violation of Regulation 8	Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	
		Restoration on time as per Regulation (in days)	Actual Restoration on time (in days)
NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL

*Reviewed*  
22/12/2023

Outage details of AC Transmission Line: Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of June-2023

(i) Element wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	61	61	99.95	
Power Transformer/ Inter connecting Transformer (CT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(ii) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Jun-23	99.974
HVDC Transmission System	NA	NA

(iii) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Jun-23	1	61

(iv) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(v) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6 % Availability Prescribed	Actual % Availability	Violation of Regulation 6 Restoration time on time as per Regulation 8 (in days)	Actual Restoration Time (in days)	Compensation Paid (in Rs)
NIL	NIL	NIL	NIL	NIL	NIL
Total					

*Permit*  
22/12/2023

Outage details of AC Transmission Line/ Power Transformer/ Static VAR Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of July-2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.00	
Power Transformer/ Inter connecting Transformer (CT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Jul-23	100
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Jul-23	0	0

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6		Violation of Regulation 8		Actual Restoration Time (in days)	Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation 8 (in days)	Actual Restoration Time (in days)		
NIL	NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL	NIL

*Permit*  
22/12/2023

Outage details of AC Transmission Line/ Power Transformer/ Static VAR Compensator / Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus Reactors for the month of August-2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.00	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Aug-23	100
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Aug-23	0	0

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6	Violation of Restoration time as per Regulation 8	Actual Restoration Time (in days)	Compensation Paid (in Rs)
NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL

*Handwritten signature and date:*  
 22/12/2023

Outage details of AC Transmission Line/ Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of September-2023

(i) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	1151	1151	98.98	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(ii) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Sep-23	99.491
HVDC Transmission System	NA	NA

(iii) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Sep-23	2	1151

(iv) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(v) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6	Violation of Regulation 8	Restoration time as per Regulation 8 (in days)	Actual Restoration time (in days)	Compensation Paid (in Rs)
NIL	NIL	NIL	NIL	NIL	NIL
Total					

*Handwritten signature and date:*  
 22/12/2023

Outage details of AC Transmission Line/ Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of April 2023

220KV

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	99.53	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Apr-23	99.766
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Apr-23	0	0

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6		Violation of Regulation 8		Actual Restoration time (in days)	Actual Restoration time (in days)	Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)			
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL	NIL	NIL

*Remade*  
22/12/2023

Outage details of AC Transmission Line/ Power Transformer/ Static V-A Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of May-2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	99.83	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	May-23	99.915
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
May-23	0	0

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6		Violation of Regulation 8		Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation 8 (in days)	Actual Restoration Time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL

*Signature*  
22/12/2023



Outage details of AC Transmission Line/ Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back) and Bi-Pole Links/ Line Reactors/ Bus reactors for the month of June-2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	99.95	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Jun-23	99.974
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Jun-23	0	0

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6	Violation of Regulation 8	Compensation Paid (in Rs)
	% Availability Prescribed	Restoration time as per Regulation 8 (in days)	
	Actual % Availability	Actual Restoration time (in days)	
NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL

*Handwritten signature and date:*  
 22/12/2023

Outage details of AC Transmission Line/ Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus Reactor for the month of July-2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (in minutes)	Total outage time during month considered for computation of availability (in minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.00	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Jul-23	100
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Jul-23	0	0

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 5	Violation of Restoration time as per Regulation 8	Actual Restoration Time (in days)	Compensation Paid (in Rs)
NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL

*Handwritten signature and date:*  
 22/12/2023

Outage details of AC Transmission Line/ Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of August-2023

(i) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.00	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(ii) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Aug-23	100
HVDC Transmission System	NA	NA

(iii) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Aug-23	0	0

(iv) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(v) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6	Violation of Regulation 8	Actual Restoration Time (in days)	Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation 8 (in days)	Actual Restoration Time (in days)
NIL	NIL	NIL	NIL	NIL
Total				NIL

*Signature*  
22/11/2023

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ Series Compensator/ HVDC (Back to back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of September-2023

(i) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	98.98	
Power Transformer/ Inter connecting Transformer (CT)	0	0	100.00	
Reactors	0	0	100.00	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month.

(ii) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Sep-23	99.491
HVDC Transmission System	NA	NA

(iii) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Sep-23	0	0

(iv) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(v) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 5		Violation of Regulation 8		Actual Restoration Time (in days)	Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation 8 (in days)	Actual Restoration time (in days)		
NIL	NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL	NIL

*Approved*  
22/12/2023



Reason: Approved  
 Date: 2023.05.05 17:06:12 IST  
 Engineer  
 Designation: Superintending  
 Digitally signed by Mukul Bhargava

**Signature valid**

Superintending Engineer (SOLD)  
 RRVPNL, Jaipur

Copy forwarded to the M/s Maru Transmission Service Company Limited, 31(A), 6<sup>th</sup> Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganeer Road, Jaipur-302019, Rajasthan.

(Mukul Bhargava)  
 Superintending Engineer (SOLD)  
 RRVPNL, Jaipur

This is for your kind information and further necessary action please.

99.533 %	Availability of AC lines
100.000 %	Availability of Power Transformers / ICTs
100.000 %	Availability of bus reactors / switchable line reactors
99.766 %	Total transmission system availability

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Maru Transmission Services Company Limited (MTSCL) for the month April 2023 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

Accordingly, the element wise availability & total transmission system availability of M/s Maru Transmission Service Company Limited (MTSCL) for the month April 2023 are certified provisionally as under:-

Ref:- Letter No. MTSCL/SLDC/02052023/01 Dated 02.05.2023 of M/s MTSCL.

Sub:- Certification of Transmission System Availability of 400/ 220/ 132 KV GSS Deedwana and associated elements under RAJ/PP-2, for M/s Maru Transmission Services Company Limited (MTSCL) for the month of April 2023.

RUVNL, Jaipur

The Superintending Engineer (Billing),

No. RVP/SE (SOLD)/KEN-1/F. /D. Dated:-

[Corporate Identity Number (CIN): U40109RJ2000SGC016485]  
 Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005  
 OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)  
 SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403  
 E-mail: sa.sold@rvpn.co.in website: www.http://energy.rajashtan.gov.in/rvpnl

**RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED**

**RVPN**  
 An ISO 9001:2015  
 Certified Company





Rajkaj Ref No. : 3985945

Reason: Approved  
Date: 2023.06.17:51:31 IST  
Engineer  
Designation: Superintending  
Digitally signed by Mukul Bhargava  
Signature valid  
Superintending Engineer (SOLD)  
RRVPNL, Jaipur

Rajasthan,  
Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sangner Road, Jaipur-302019,  
Copy forwarded to the M/s Maru Transmission Service Company Limited, 31(A), 6<sup>th</sup>

(Mukul Bhargava)  
Superintending Engineer (SOLD)  
RRVPNL, Jaipur

This is for your kind information and further necessary action please.

Availability of AC lines	99.831 %
Availability of Power Transformers / ICTs	100.000 %
Availability of bus reactors / switchable line reactors	100.000 %
Total transmission system availability	99.915 %

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Maru Transmission Services Company Limited (MTSCL) for the month May' 2023 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.  
Accordingly, the element wise availability & total transmission system availability of M/s Maru Transmission Service Company Limited (MTSCL) for the month May' 2023 are certified provisionally as under:-

Sub:- Certification of Transmission System Availability of 400/ 220/ 132 KV GSS Deedwana and associated elements under RAJ/PP-2, for M/s Maru Transmission Services Company Limited (MTSCL) for the month of May' 2023.  
Ref:- Letter No. MTSCL/SLDC/02062023/01 Dated 02.06.2023 of M/s MTSCL.

The Superintending Engineer (Billing),  
RUVNL, Jaipur

No. RVPN/SE (SOLD)/XEN-1/F. /D. Dated:-

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED  
[Corporate Identity Number (CIN): U40109RJ2000SGC016485]  
Regd. Office: Vidut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005  
OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)  
SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403  
E-mail: se.sold@rvpn.co.in website: www.http://energy.rajasthan.gov.in/rvprnl

RRVPN  
An ISO 9001:2015  
Certified Company





Rajkaj Ref No. : 4196446

Reason: Approved  
Date: 2023.07.07 17:47:49 IST  
Engineer  
Designation: Superintending  
Digitally signed by Mukul Bhargava  
**Signature valid**  
RRV/PNL, Jaipur  
Superintending Engineer (SOLD)

Copy forwarded to the M/s Maru Transmission Service Company Limited, 31(A), 6<sup>th</sup> Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganer Road, Jaipur-302019, Rajasthan.

(Mukul Bhargava)  
Superintending Engineer (SOLD)  
RRV/PNL, Jaipur

This is for your kind information and further necessary action please.

99.948 %	Availability of AC lines
100.000 %	Availability of Power Transformers / ICTs
100.000 %	Availability of bus reactors / switchable line reactors
99.974 %	Total transmission system availability

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Maru Transmission Services Company Limited (MTSCL) for the month June' 2023 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer. Accordingly, the element wise availability & total transmission system availability of M/s Maru Transmission Service Company Limited (MTSCL) for the month June' 2023 are certified provisionally as under:-

Sub:- Certification of Transmission System Availability of 400/ 220/ 132 KV GSS Deedwana and associated elements under RAJ/PP-2, for M/s Maru Transmission Services Company Limited (MTSCL) for the month of June' 2023.  
Ref:- Letter No. MTSCL/SLDC/03072023/01 Dated 03.07.2023 of M/s MTSCL.

No. RVPN/SE (SOLD)/XEN-1/F. /D.  
Dated:-  
The Superintending Engineer (Billing),  
RVN/L, Jaipur

E-mail: [esold@rvpn.co.in](mailto:esold@rvpn.co.in) website: [www.energy.rajsasthan.gov.in/rvpnl](http://www.energy.rajsasthan.gov.in/rvpnl)  
SLDC BUILDING, HEERAPOURA, Jaipur-302024 Tel. No. 0141-2250403

**RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED**  
[Corporate Identity Number (CIN): U40109RJ2000SGC016485]  
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005  
OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)

RRV/PNL  
An ISO 9001:2015  
Certified Company





Rajkaj Ref No. : 4457163

Signature valid  
Digitally signed by Mukul Bhargava  
Designation: Superintending  
Engineer  
Date: 2023.08.07:37:53 IST  
Reason: Approved

Superintending Engineer (SOLD)  
RRVFNL, Jaipur

Rajasthan.

Copy forwarded to the M/s Maru Transmission Service Company Limited, 31(A), 6<sup>th</sup> Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganeer Road, Jaipur-302019.

(Mukul Bhargava)  
Superintending Engineer (SOLD)  
RRVFNL, Jaipur

This is for your kind information and further necessary action please.

100.00 %	Availability of AC lines
100.000 %	Availability of Power Transformers / ICTs
100.000 %	Availability of bus reactors / switchable line reactors
100.00 %	Total transmission system availability

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Maru Transmission Services Company Limited (MTSCL) for the month July 2023 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

Accordingly, the element wise availability & total transmission system availability of M/s Maru Transmission Service Company Limited (MTSCL) for the month July 2023 are certified provisionally as under:-

Sub:- Certification of Transmission System Availability of 400/ 220/ 132 KV GSS Deedwana and associated elements under RAJ/PP-2, for M/s Maru Transmission Services Company Limited (MTSCL) for the month of July 2023.

Ref:- Letter No. MTSCL/SLDC/02082023/01 Dated 02.08.2023 of M/s MTSCL.  
The Superintending Engineer (Billing),  
RUVNL, Jaipur  
No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D.  
Dated:-

Corporate Identity Number (CIN): U40109RJ2000SGC016485]  
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005  
OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)  
SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403  
E-mail: se.sold@rvpn.co.in website: www.http://energy.rajasthan.gov.in/rvpnl



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED





Rajkaj Ref No. : 4665438

Reason: Approved  
Date: 2023.09.08 18:33:02 IST  
Engineer  
Designation: Superintending  
Digitally signed by Mukul Bhargava

Signature valid

Superintending Engineer (SOLD)  
RRVFNL, Jaipur

Rajasthan.

Copy forwarded to the M/s Maru Transmission Service Company Limited, 31(A), 6<sup>th</sup> Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganeer Road, Jaipur-302019,

Superintending Engineer (SOLD)  
(Mukul Bhargava)  
RRVFNL, Jaipur

This is for your kind information and further necessary action please.

100.00 %	Availability of AC lines
100.000 %	Availability of Power Transformers / ICTs
100.000 %	Availability of bus reactors / switchable line reactors
100.00 %	Total transmission system availability

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Maru Transmission Services Company Limited (MTSCL) for the month August' 2023 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.  
Accordingly, the element wise availability & total transmission system availability of M/s Maru Transmission Service Company Limited (MTSCL) for the month August' 2023 are certified provisionally as under:-

Sub:- Certification of Transmission System Availability of 400/ 220/ 132 KV GSS Deedwana and associated elements under RAJ/PP-2, for M/s Maru Transmission Services Company Limited (MTSCL) for the month of August' 2023.  
Ref:- Letter No. MTSCL/SLDC/02092023/01 Dated 02.09.2023 of M/s MTSCL.

RUVNL, Jaipur

The Superintending Engineer (Billing),

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D.

Dated:-

E-mail: [ss.sold@rpn.co.in](mailto:ss.sold@rpn.co.in) website: [www.rpn.co.in](http://www.rpn.co.in) website: <http://energy.rajasthan.gov.in/rvpnl>  
SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)  
Regd. Office: Vidyt Bhawan, Jangpali, Jyoti Nagar, Jaipur-302005  
[Corporate Identity Number (CIN): U40109RJ2000SGC016485]

**RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED**

RRVFNL  
An ISO 9001:2015  
Certified Company





Rajkaj Ref No. : 4853727

Reason: Approved  
Date: 2023.10.07:59:10 IST  
Engineer  
Designation: Superintending  
Digitally signed by Mukul Bhargava  
Signature valid

Superintending Engineer (SOLD)  
RRVPL, Jaipur

Rajasthan.

Copy forwarded to the M/s Maru Transmission Service Company Limited, 31(A), 6<sup>th</sup> Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sangner Road, Jaipur-302019,

Superintending Engineer (SOLD)  
RRVPL, Jaipur  
(Mukul Bhargava)

This is for your kind information and further necessary action please.

Availability of AC lines	98.982 %
Availability of Power Transformers / ICTs	100.000 %
Availability of bus reactors / switchable line reactors	100.000 %
Total transmission system availability	99.491 %

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Maru Transmission Services Company Limited (MTSCL) for the month September 2023 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and accordingly, the element wise availability & total transmission system availability of M/s Maru Transmission Service Company Limited (MTSCL) for the month September 2023 are certified provisionally as under:-

Sub:- Certification of Transmission System Availability of 400/ 220/ 132 KV GSS Deedwana and associated elements under RAJ/PP-2, for M/s Maru Transmission Services Company Limited (MTSCL) for the month of September 2023.  
Ref:- Letter No. MTSCL/SLDC/03102023/01 Dated 03.10.2023 of M/s MTSCL.

The Superintending Engineer (Billing),  
RUVNL, Jaipur

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D.  
Dated:-

Corporate Identity Number (CIN): U40109RJ2000SGC016485  
Regd. Office: Vidut Bhawan, Japath, Jyoti Nagar, Jaipur-302005  
OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)  
SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403  
E-mail: sesold@rvpn.co.in website: www.http://energy.rajasthan.gov.in/rvpnl

RRVPLN  
An ISO 9001:2015  
Certified Company



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

SAIFI & SAIDI of M/S Maru Transmission Service Limited (MTSCL) for the Year 2023-24 (April 23 to Sept 23)

Sr. No.	Month	400 KV						220 KV														
		Line		Transformer		Reactor		Line		Transformer		Total Interruption										
		Freq. of tripping	Duration of tripping	Freq. of tripping	Duration of tripping	Freq. of tripping	Duration of tripping	Total Interruption Freq. of tripping	Total Interruption Duration of tripping	Total No. of GSS	SAIFI	SAIDI	Freq. of tripping	Duration of tripping	Freq. of tripping	Duration of tripping	Total Interruption Freq. of tripping	Total Interruption Duration of tripping	Total No. of GSS	SAIFI	SAIDI	
1	Apr-23	2	501	0	0	0	0	2	501	1	2	501	0	0	0	0	0	0	0	1	0.00	0.00
2	May-23	1	171	0	0	0	0	1	171	1	1	171	0	0	0	0	0	0	0	1	0.00	0.00
3	Jun-23	1	61	0	0	0	0	1	61	1	1	61	0	0	0	0	0	0	0	1	0.00	0.00
4	Jul-23	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	0.00	0.00
5	Aug-23	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	0.00	0.00
6	Sep-23	2	1151	0	0	0	0	2	1151	1	2	1151	0	0	0	0	0	0	0	1	0.00	0.00

*Shay*

*PR*