

Information to be submitted by Transmission Licensee to the Commission - PPP-10 TPTSL

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of October 2021

(I) Element Wise Transmission System availability - 132-UV

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	31	31	99.9993	
Power Transformer/ Inter connecting Transformer (ICT) Reactors	0	0	100.0000	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Oct-21	99.83
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Oct-21	0.2	6.2

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6			Violation of Regulation 8			Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	Actual Restoration Time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL
Total							NIL

Pradeep

878

Information to be submitted by Transmission Licensee to the Commission - PPP-10 TPTSL

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of November 2021

(I) Element Wise Transmission System availability - 132-VV

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.0000	
Power Transformer/ Inter connecting Transformer (ICT) Reactors	0	0	100.0000	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	
Note - Total Outage time shall be summation of outage time of all elements during the month				

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Nov-21	99.75
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Nov-21	0	0.00

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6			Violation of Regulation 8		
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	Actual Restoration time (in days)	Compensation Paid (in Rs)
NIL	NIL	NIL	NIL	NIL	NIL	NIL
Total						
	NIL	NIL	NIL	NIL	NIL	NIL

Revised

Information to be submitted by Transmission Licensee to the Commission - PPP-10 TPTSL
 Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus Reactors/ Bus reactors for the month of December 2021

(I) Element Wise Transmission System availability - 132KV

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	22	22	99.9995	
Power Transformer/ Inter connecting Transformer (ICT)	24	24	99.9995	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Dec-21	99.986
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Dec-21	0.6	9.2

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6		Violation of Regulation 8		Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL

Revised

680

Information to be submitted by Transmission Licensee to the Commission - PPP-10 TPTSL

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of JANUARY- 2022

(I) Element Wise Transmission System availability - 132 kv

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.0000	
Power Transformer/ Inter connecting Transformer (ICT) Reactors	0	0	100.0000	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	
Note - Total Outage time shall be summation of outage time of all elements during the month				

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Jan-22	99.775
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Jan-22	0	0.00

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6			Violation of Regulation 8			Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	Actual Restoration time (in days)	Compensation Paid (in Rs)	
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL
Total							

Signature

Information to be submitted by Transmission Licensee to the Commission - PPP-10 TPTSL

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of FEBRUARY- 2022

(i) Element Wise Transmission System availability - 132 KV

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.0000	
Power Transformer/ Inter connecting Transformer (ICT) Reactors	0	0	100.0000	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	
Note - Total Outage time shall be summation of outage time of all elements during the month				

(ii) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Feb-22	99.767
HVDC Transmission System	NA	NA

(iii) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Feb-22	0	0.00

(iv) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(v) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6			Violation of Regulation 8			Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	Actual Restoration Time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL
Total							
NIL							

Signature

682

Information to be submitted by Transmission Licensee to the Commission - PPP-10 TPTSL

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus Reactors for the month of MARCH- 2022

(I) Element Wise Transmission System availability - 132.44

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.00	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.00	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Mar-22	99.441
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Mar-22	0	0.00

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6		Violation of Regulation 8		Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL

Paal

687