

Element wise Outage Details of Alipurduar Transmission Limited for FY 2021 - 22

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400 KV Alipurduar - Binaguri D/C Ckt-3	28-10-2021 13:32	28-10-2021 17:46	04:14	00:00	00:00	00:00	Line Tripped on Y-B Fault Distance 73.2 km from Binaguri & 32.1 km from Alipurduar SS. Charging Code ER/1267	99.43%
400 KV Alipurduar - Binaguri D/C Ckt-3	06-12-2021 09:44	06-12-2021 19:12	000:00	009:28	000:00	000:00	Shutdown Taken by Alipurduar (PGCIL) End for PLCC Maintenance. Discharging Code ER/326 Charging Code ER/376	100.00%
400 KV Alipurduar - Binaguri D/C Ckt-3	07-12-2021 09:34	07-12-2021 18:51	0:00	9:17	0:00	0:00	Shutdown Taken by Alipurduar (PGCIL) End for PLCC Maintenance Discharging Code ER/424 Charging Code ER/476	
400 KV Kishanganj - Darbhanga D/C Ckt-2	25-01-2022 18:48	25-01-2022 20:02	1:14	0:00	0:00	0:00	Tripped due CB Gas Compartment Aux. Relay (KP22) mal operation.Charging Code ER/1633	99.83%
400 KV Alipurduar - Binaguri D/C Ckt-3	22-01-2022 23:40	28-01-2022 10:11	0:00	0:00	0:00	130:31	Line Hand tripped due to voltage Regulaton Shutdown Code ER/01/1465 Closing Code ER/01/1755	100.00%
400 KV Alipurduar - Binaguri D/C Ckt-4	02-01-2022 00:37	21-01-2022 10:23	0:00	0:00	0:00	465:46	Line Hand tripped due to voltage Regulaton Shutdown Code ER/01/031 Closing Code ER/01/1333	100.00%
400 KV Alipurduar - Binaguri D/C Ckt-4	01-02-2022 00:05	28-02-2022 23:59	0:00	0:00	0:00	671:54	Line Hand tripped due to voltage Regulaton Shutdown Code ER/01/1985. Outage hours considered up to 28th Feb 23:59. Line still not charged.	100.00%
400 KV Kishanganj - Darbhanga D/C Ckt-1	24-03-2022 09:31	31-03-2022 23:59	0:00	182:28	0:00	0:00	Shutdown Taken by PMTL for LILO Work at Saharsa SS. Outage considered till 31st March. Line still not charged. Discharging Code ER/03/1254	100.00%
400 KV Kishanganj - Darbhanga D/C Ckt-2	24-03-2022 09:32	31-03-2022 23:59	0:00	182:27	0:00	0:00	Shutdown Taken by PMTL for LILO Work at Saharsa SS. Outage considered till 31st March. Line still not charged. Discharging Code ER/03/1255	100.00%
400 KV Alipurduar - Binaguri D/C Ckt-3	07-03-2022 12:10	07-03-2022 23:25	0:00	0:00	0:00	11:15	Line tripped on B-ph to E/F, 73.2Km from Alipurduar SS. Charging Code ER/03/409. Line tripped due to Tree branch infridged in the induction zone. There was severe ROW in between Tower no. 130 & 131. We have approched Police, Local & District administration to resolve ROW since last six months. Letter attached herewith. However villagers were adamant to provide access to cut the trees. Due to heavy loading in summer sag increased and tree branch came in induction zone and line tripped.	100.00%
400 KV Alipurduar - Binaguri D/C Ckt-3	11-03-2022 11:48	11-03-2022 12:29	0:00	0:00	0:00	0:41	Line tripped due to B-ph to E/F, 73 Km from Alipurduar SS. Charging Code ER/03/657. Line again tripped due to reason mentioned above.	
400 KV Alipurduar - Binaguri D/C Ckt-3	19-03-2022 11:49	21-03-2022 20:56	0:00	0:00	0:00	57:07	Line tripped due to B-ph to E/F, 73 Km from Alipurduar SS. Charging Code ER/03/1127 Line again tripped due to reason mentioned above.	
400 KV Alipurduar - Binaguri D/C Ckt-4	01-03-2022 00:00	11-03-2022 13:00	0:00	0:00	0:00	253:00	Line Hand tripped due to voltage Regulaton. Shutdown Code ER/01/1985. Charging Code ER/03/658	100.00%

II

Elements where restoration time has exceeded the standards specified in Regulation 5 (b)

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III

Details of compensation paid by the inter-State transmission licensee

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5 (b)		Compensation paid (in Rs.)
	% Availability rescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL