

Element wise Outage Details of Adani Transmission (India) Limited (Asset 1 HVAC) for FY 2022 - 23

Element Name	Outage		Restoration		Duration of Outage Attributable to					
	Date	Time	Date	Time	Inter-State Transmission LICENCEE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILAB LE	Reason of Outage	% Availability
400kV Mohinderg arh (ATIL) - Dhanonda (HVPNL) Ckt-1	25-Aug-22	18:07:00	25-Aug-22	21:52:00	0:00:00	7:30:00	0:00:00	0:00:00	Shutdown was taken by HVPNL (400 kV Dhanonda SS) for isolator maintenance work at their end.	100
400kV Mohinderg arh (ATIL) - Bhiwani (PG) Ckt-1	25-Nov-22	9:57:00	25-Nov-22	18:03:00	8:06:00	0:00:00	0:00:00	0:00:00	Planned outage for Annual Maintenance and Bay equipment Testing of 400 KV MAHINDERGARH (APL)-Bhiwani (HV) (ATIL) CKT-1. Outage Code NRLDC : 6725	100
400kV Mohinderg arh (ATIL) - Bhiwani (PG) Ckt-2	7-Dec-22	8:22:00	7-Dec-22	20:11:00	11:49:00	0:00:00	0:00:00	0:00:00	Planned outage for Annual Maintenance and Bay equipment Testing of 400 KV MAHINDERGARH (APL)-Bhiwani (HV) (ATIL) CKT-2.	100
400kV Mohinderg arh (ATIL) - Dhanonda (HVPNL) Ckt-1	8-Dec-22	13:31:00	8-Dec-22	19:03:00	5:32:00	0:00:00	0:00:00	0:00:00	Planned outage for Annual Maintenance and Bay equipment Testing of 400 KV MAHINDERGARH(APL)- DHANODA(HV) (ATIL) CKT-1	
400kV Mohinderg arh (ATIL) - Dhanonda (HVPNL) Ckt-2	9-Dec-22	12:51:00	9-Dec-22	19:15:00	6:24:00	0:00:00	0:00:00	0:00:00	Planned outage for Annual Maintenance and Bay equipment Testing of 400 KV MAHINDERGARH(APL)- DHANODA(HV) (ATIL) CKT-2	
400kV Mohinderg arh (ATIL) - Bhiwani (PG) Ckt-1	21-Jan-23	8:39:00	21-Jan-23	20:43:00	0:00:00	12:04:00	0:00:00	0:00:00	Outage approved by RLDC (RQ120451) for line crossing work by NRSS36.	100
400kV Mohinderg arh (ATIL) - Bhiwani (PG) Ckt-2	21-Jan-23	8:40:00	21-Jan-23	20:44:00	0:00:00	12:04:00	0:00:00	0:00:00	Outage approved by RLDC (RQ120452) for line crossing work by NRSS36.	

Element Name	Outage		Restoration		Duration of Outage Attributable to					
	Date	Time	Date	Time	Inter-State Transmission LICENCEE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILAB LE	Reason of Outage	% Availability
400kV Mohindergarh (ATIL) - Bhiwani (PG) Ckt-2	4-Feb-23	16:53:00	4-Feb-23	20:54:00	4:01:00	0:00:00	0:00:00	0:00:00	400kV Mohindergarh (ATIL) - Bhiwani (PG) Ckt-2 Emergency shutdown taken by PGCIL Bhiwani end for attending damaged isolator finger & female contact at their end.	100

II

Elements where restoration time has exceeded the standards specified in Regulation 5 (b)

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III

Details of compensation paid by the inter-State transmission licensee

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5 (b)		Compensation paid (in Rs.)
	% Availability rescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL