

**Element wise Outage Details of Adani Transmission (India) Limited (Asset 2 HVAC) for FY 2023 - 24**

Element Name	Outage		Restoration		Duration of Outage Attributable to						% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage		
400KV SAMI-DEHGAM CKT-1	1-Apr-23	0:00:00	1-Apr-23	6:27:00	0:00:00	0:00:00	0:00:00	6:27:00	400KV SAMI-DEHGAM LINE- 1 manually discharged against code no WR/3757 at 13:13 hrs. on 30.03.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/02)		99.95
400KV MUNDRA-SAMI CKT-1	1-Apr-23	0:00:00	1-Apr-23	6:07:00	0:00:00	0:00:00	0:00:00	6:07:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/3756 at 13:16 hrs. on 30.03.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/01)		
400KV SAMI-DEHGAM CKT-1	1-Apr-23	21:17:00	2-Apr-23	11:02:00	0:00:00	0:00:00	0:00:00	13:45:00	400KV SAMI-DEHGAM LINE- 1 manually discharged against code no WR/99 at 21:17 hrs. on 01.04.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/133)		
400KV MUNDRA-SAMI CKT-1	1-Apr-23	21:18:00	2-Apr-23	11:07:00	0:00:00	0:00:00	0:00:00	13:49:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/98 at 21:18 hrs. on 01.04.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/132)		
400KV SAMI-DEHGAM CKT-1	2-Apr-23	22:18:00	3-Apr-23	9:24:00	0:00:00	0:00:00	0:00:00	11:06:00	400KV SAMI-DEHGAM LINE- 1 manually discharged against code no WR/175 at 22:18 hrs. on 02.04.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/212)		
400KV MUNDRA-SAMI CKT-1	2-Apr-23	22:11:00	3-Apr-23	9:35:00	0:00:00	0:00:00	0:00:00	11:24:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/174 at 22:11hrs. on 02.04.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/211)		
400KV MUNDRA-SAMI CKT-1	4-Apr-23	6:13:00	4-Apr-23	6:13:00	0:00:00	0:00:00	0:00:00	0:00:00	400KV MUNDRA-SAMI LINE-1 Auto-reclose successfully operated on B-Ph-E, Fault Current- B-Ph- 4.58 KA, Fault Distance- 6.9 KM, Zone-1 at 06:13Hrs on dt.04.04.2023. During line petrolling Kite Thread Found by Line team During petrolling.		
400KV SAMI-DEHGAM CKT-2	6-Apr-23	6:23:00	6-Apr-23	6:23:00	0:00:00	0:00:00	0:00:00	0:00:00	Sami-Dehgam line-2 Auto reclose successfully operated in Y phase due to Hevey rain and thunderstorm in said area.		
400KV MUNDRA-SAMI CKT-1	17-Apr-23	4:31:00	17-Apr-23	4:31:00	0:00:00	0:00:00	0:00:00	0:00:00	400KV MUNDRA-SAMI LINE-1 Auto-reclose successfully operated on Y-Ph-E, Fault Current- Y-Ph- 2.34 KA, Fault Distance- 103.4 KM, Zone-1 at 04:31 Hrs on dt.17.04.2023.		
400KV MUNDRA-SAMI CKT-2	28-Apr-23	10:48:00	28-Apr-23	13:50:00	3:02:00	0:00:00	0:00:00	0:00:00	400KV APMuL Sami Line 2 manually discharged against code no WR/3133 at 10:48 hrs. on 28.04.2023 for CT oil sampling work at APMUL end outage taken by APL Mundra Team. (Charging Code :WR/3148)		
400KV MUNDRA-SAMI CKT-1	30-Apr-23	14:04:00	30-Apr-23	14:04:00	0:00:00	0:00:00	0:00:00	0:00:00	400KV MUNDRA-SAMI LINE-1 Auto-reclose successfully operated on Y-Ph-E, Fault Current- Y-Ph- 1.48 KA, Fault Distance- 194.1 KM, Zone-1 at 14:04 Hrs on dt.30.04.2023.		

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
400kV MUNDRA-SAMI CKT-1	29-May-23	1:50:00	29-May-23	8:04:00	0:00:00	0:00:00	6:14:00	0:00:00	400KV MUNDRA-SAMI LINE- 1 manually discharged against code no WR/3090 at 01:50 hrs. on 29.05.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/3112)	100
400kV BUS REACTOR-1 AT MUNDRA	8-Jun-23	9:47:00	8-Jun-23	19:53:00	0:00:00	0:00:00	10:06:00	0:00:00	Made OFF as per SLDC instructions for voltage control S/D Code WR/207 charged code WR/227	
400kV BUS REACTOR-2 AT MUNDRA	8-Jun-23	9:50:00	8-Jun-23	19:54:00	0:00:00	0:00:00	10:04:00	0:00:00	Made OFF as per SLDC instructions for voltage control S/D Code WR/207 charged code WR/227	
400kV MUNDRA-SAMI CKT-2	16-Jun-23	16:00:00	16-Jun-23	17:49:00	0:00:00	0:00:00	0:00:00	1:49:00	Sami-Mundra Line-2 tripped on B-phase earth fault at 16:00 hrs on dt.16.06.2023. During fault duration heavy rain & wind blown at the fault location (Biporjoy effect). (Charging Code:WR/1912)	100
400kV MUNDRA-SAMI CKT-1	18-Jun-23	16:16:00	18-Jun-23	20:23:00	0:00:00	0:00:00	0:00:00	4:07:00	Emergency outage taken by APMUL TEAM for Top Jumper connection work of R-phase Line CVT of 400KV Mundra-Sami line-1 at Mundra end. 400KV Mundra-Sami line-1 manually discharged against grid code: WR/2107. (Charging Code:WR/2122)  Note: R-phase line CVT jumper broken during biporjoy cyclone heavy rain & wind blown at Mundra end	
400kV SAMI-DEHGAM CKT-2	6-Jul-23	0:36:00	6-Jul-23	0:36:00	0:00:00	0:00:00	0:00:00	0:00:00	Sami-Dehgām line-2 Auto reclose successfully operated in B phase at 00:36 on dt.06.07.2023 due to Hevey rain and Wind pressure with lighting in said area.	100
400kV BUS REACTOR-1 AT MUNDRA	1-Sep-23	0:00:00	17-Sep-23	1:49:00	0:00:00	0:00:00	0:00:00	385:49:00	Made OFF as per SLDC instructions for voltage control S/D Code 367 charged code 741	100
400kV BUS REACTOR-3 AT MUNDRA	1-Sep-23	0:00:00	17-Sep-23	23:48:00	0:00:00	0:00:00	0:00:00	407:48:00	Made OFF as per SLDC instructions for voltage control S/D Code 367 charged code 741	
400kV BUS REACTOR-2 AT MUNDRA	1-Sep-23	0:00:00	17-Sep-23	2:33:00	0:00:00	0:00:00	0:00:00	386:33:00	Made OFF as per SLDC instructions for voltage control S/D Code 389 charged code 741	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
400KV SAMI-DEHGAM CKT-2	17-Sep-23	2:10:00	18-Sep-23	18:11:00	0:00:00	0:00:00	0:00:00	40:01:00	400KV Sami-Dehgam line-2 manually discharged at 02:10 hrs on dt.17.09.2023, against code no WR/1612 for voltage regulation as per instruction ALDC. (Charging Code:WR/1759).	
400KV MUNDRA-SAMI CKT-2	17-Sep-23	2:11:00	18-Sep-23	18:02:00	0:00:00	0:00:00	0:00:00	39:51:00	400KV APL-Mundra-Sami line-2 manually discharged at 02:11 hrs on dt.17.07.2023, against code no WR/1611 for voltage regulation as per instruction ALDC. (Charging Code:WR/1758).	
400KV SAMI-DEHGAM CKT-1	1-Jan-23	0:00:00	2-Jan-23	10:19:00	0:00:00	0:00:00	0:00:00	34:19:00	400KV SAMI-DEHGAM LINE- 1 manually discharged against code no WR/4883 as per instruction received from ALDC for bus voltage control. (Charging Code : WR/136)	
400KV MUNDRA-SAMI CKT-1	1-Jan-23	0:00:00	2-Jan-23	10:13:00	0:00:00	0:00:00	0:00:00	34:13:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/4842 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/134)	
400KV MUNDRA-SAMI CKT-1	2-Jan-23	20:13:00	5-Jan-23	11:58:00	0:00:00	0:00:00	0:00:00	63:45:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/224 at 20:13 hrs. on 02.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/570)	
400KV SAMI-DEHGAM CKT-1	3-Jan-23	0:08:00	5-Jan-23	12:42:00	0:00:00	0:00:00	0:00:00	60:34:00	400KV SAMI-DEHGAM LINE- 1 manually discharged against code no WR/246 at 00:08 hrs. on 03.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code : WR/571)	
400/220KV ICT-2 AT MUNDRA	5-Jan-23	12:21:00	5-Jan-23	21:46:00	9:25:00	0:00:00	0:00:00	0:00:00	Made OFF for Annual Maintenance S/D Code WR/572 charged code WR/633	
400KV SAMI-DEHGAM CKT-1	6-Jan-23	0:28:00	7-Jan-23	11:28:00	0:00:00	0:00:00	0:00:00	35:00:00	400KV SAMI-DEHGAM LINE- 1 manually discharged against code no WR/647 at 00:28 hrs. on 06.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code : WR/858)	
400KV MUNDRA-SAMI CKT-1	6-Jan-23	0:27:00	7-Jan-23	11:22:00	0:00:00	0:00:00	0:00:00	34:55:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/646 at 00:27 hrs. on 06.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :857)	
400KV SAMI-DEHGAM CKT-1	14-Jan-23	0:21:00	14-Jan-23	18:19:00	0:00:00	0:00:00	0:00:00	17:58:00	400KV SAMI-DEHGAM LINE- 1 manually discharged against code no WR/1823 at 00:22 hrs. on 14.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/1926)	
400KV SAMI-DEHGAM CKT-2	14-Jan-23	16:51:00	14-Jan-23	19:03:00	0:00:00	0:00:00	0:00:00	2:12:00	400KV SAMI-DEHGAM LINE- 2 Tripped on R-Y Ph-Ph Fault occurred at TWFL Distance 112 KM at 16:51 hrs. on dt.14.01.2023 . (Charging Code :WR/1937) Fault occurred due to kite thread Line team patrolling mail attached with image.	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
400KV MUNDRA-SAMI CKT-1	14-Jan-23	0:22:00	14-Jan-23	18:07:00	0:00:00	0:00:00	0:00:00	17:45:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/1822 at 00:21 hrs. on 14.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/1902)	98.97
400KV MUNDRA-SAMI CKT-2	14-Jan-23	16:55:00	14-Jan-23	19:51:00	0:00:00	0:00:00	0:00:00	2:56:00	400KV SAMI-MUNDRA LINE- 2 manually discharged at 16:55 hrs because Fire occurred at R & Y-Phase platform of FSC-2 of 400KV Sami-Mundra line-2 at the same of R-Y Ph-Ph fault tripping of 400KV Sami-Dehgam line-2 at 16:51 on dt.14.01.2023. (Charging Code :WR/1943)	
400KV SAMI-DEHGAM CKT-1	14-Jan-23	22:00:00	16-Jan-23	7:48:00	0:00:00	0:00:00	0:00:00	33:48:00	400KV SAMI-DEHGAM LINE- 1 manually discharged against code no WR/1961 at 22:00 hrs. on 14.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/2091)	
400KV MUNDRA-SAMI CKT-1	14-Jan-23	22:02:00	16-Jan-23	7:42:00	0:00:00	0:00:00	0:00:00	33:40:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/1960 at 22:02 hrs. on 14.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/2092)	
400KV BUS REACTOR-1 AT MUNDRA	17-Jan-23	10:07:00	18-Jan-23	20:16:00	34:09:00	0:00:00	0:00:00	0:00:00	Made OFF for Annual Maintenance S/D Code WR/2325 charged code WR/2609	
400KV SAMI-DEHGAM CKT-1	25-Jan-23	4:22:00	27-Jan-23	9:51:00	0:00:00	0:00:00	0:00:00	53:29:00	400KV SAMI-DEHGAM LINE- 1 manually discharged against code no WR/3509 at 04:22 hrs. on 25.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/3745)	
400KV MUNDRA-SAMI CKT-1	25-Jan-23	4:20:00	27-Jan-23	9:15:00	0:00:00	0:00:00	0:00:00	52:55:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/3508 at 04:20 hrs. on 25.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/3746)	
400KV MUNDRA-SAMI CKT-1	28-Jan-23	11:55:00	28-Jan-23	19:24:00	0:00:00	0:00:00	0:00:00	7:29:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/3936 at 11:55 hrs. on 28.01.2023 as per instruction received from ALDC for bus voltage control. (Charging Code :WR/3991)	
400KV SAMI-DEHGAM CKT-1	29-Jan-23	1:30:00	31-Jan-23	23:59:00	0:00:00	0:00:00	0:00:00	70:29:00	400KV SAMI-DEHGAM LINE- 1 manually discharged against code no WR/4019 at 13:30 hrs. on 29.01.2023 as per instruction received from ALDC for bus voltage control. Till date line made off for high voltage.	
400KV MUNDRA-SAMI CKT-1	29-Jan-23	1:34:00	31-Jan-23	23:59:00	0:00:00	0:00:00	0:00:00	70:25:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/4018 at 01:34 hrs. on 29.01.2023 as per instruction received from ALDC for bus voltage control. Till date line made off for high voltage.	
400KV MUNDRA-SAMI CKT-1	12-Nov-23	23:05:00	16-Nov-23	9:22:00	0:00:00	0:00:00	0:00:00	82:17:00	400KV SAMI-MUNDRA LINE- 1 manually discharged against code no WR/1408 at 23:05 hrs. on 12.11.2023 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/1655 )	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
400kV BUS REACTOR-3 AT MUNDRA	21-Nov-23	10:25:00	21-Nov-23	19:37:00	0:00:00	0:00:00	0:00:00	9:12:00	Voltage control as per ALDC instruction (S/D Code: 1299 Charge code 1325)	
400kV SAMI-DEHGAM CKT-2	22-Nov-23	8:53:00	22-Nov-23	19:01:00	10:08:00	0:00:00	0:00:00	0:00:00	400KV -DEHGAM-SAMI-2 manually discharged at 08:53 Hrs against code no: WR/2468 for Annual maintenance & Testing of line equipments (Permission for charging mail sent on 18:41 Hrs_22-11-2023) (Charging Code: WR/2553)	
400kV BUS REACTOR-1 AT MUNDRA	23-Nov-23	10:00:00	23-Nov-23	20:17:00	0:00:00	0:00:00	0:00:00	10:17:00	Voltage control as per ALDC instruction (S/D Code WR 1407. Charge code1437.)	
400kV BUS REACTOR-2 AT MUNDRA	23-Nov-23	10:00:00	23-Nov-23	20:17:00	0:00:00	0:00:00	0:00:00	10:17:00	Voltage control as per ALDC instruction (S/D Code WR 1407. Charge code1437.)	
400kV SAMI-DEHGAM CKT-1	23-Nov-23	8:50:00	23-Nov-23	20:18:00	11:28:00	0:00:00	0:00:00	0:00:00	400KV -DEHGAM-SAMI-1 manually discharged at 08:50 Hrs against code no: WR/2610 for Annual maintenance & Testing of line equipments. (Permission for charging mail sent on 19:25 Hrs_23-11-2023) (Charging Code: WR/2736)	
400kV MUNDRA-SAMI CKT-1	24-Nov-23	23:09:00	25-Nov-23	7:43:00	0:00:00	0:00:00	0:00:00	8:34:00	400KV APL-Mundra-Sami line-1 manually discharged at 23:09 hrs on dt. 24.11.2023., against code no WR/2925 for voltage regulation As per Istruction ALDC, (Charging code: WR/2940)	
400kV SAMI-DEHGAM CKT-1	24-Nov-23	23:02:00	25-Nov-23	7:49:00	0:00:00	0:00:00	0:00:00	8:47:00	400KV Dehgam -Sami line-1 manually discharged at 23:02 hrs on dt. 24.11.2023., against code no WR/2926 for voltage regulation As per Istruction ALDC, (Charging code: WR/2942)	
400kV SAMI-DEHGAM CKT-1	26-Nov-23	11:20:00	26-Nov-23	11:20:00	0:00:00	0:00:00	0:00:00	0:00:00	400KV Sami-Dehgam line-1 Auto reclose successfully operated in B phase at 11:20 on dt.26.11.2023 due to Hevey rain and Wind pressure in said area.	
400kV SAMI-DEHGAM CKT-2	27-Nov-23	1:00:00	27-Nov-23	8:55:00	0:00:00	0:00:00	0:00:00	7:55:00	400KV SAMI-DEHGAM LINE- 2 manually discharged against code no WR/3219 at 01:00 hrs. on 27.11.2023 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/3255)	
400kV MUNDRA-SAMI CKT-2	27-Nov-23	0:59:00	27-Nov-23	9:08:00	0:00:00	0:00:00	0:00:00	8:09:00	400KV SAMI-MUNDRA LINE- 2 manually discharged against code no WR/3216 at 00:59 hrs. on 27.11.2023 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/3254)	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
400kV SAMI-DEHGAM CKT-2	28-Nov-23	1:09:00	28-Nov-23	8:48:00	0:00:00	0:00:00	0:00:00	7:39:00	400KV SAMI-DEHGAM LINE- 2 manually discharged against code no WR/3369 at 01:09 hrs. on 28.11.2023 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/3396)	99.34
400kV MUNDRA-SAMI CKT-2	28-Nov-23	1:12:00	28-Nov-23	8:57:00	0:00:00	0:00:00	0:00:00	7:45:00	400KV SAMI-MUNDRA LINE- 2 manually discharged against code no WR/3368 at 01:12 hrs. on 28.11.2023 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/ 3395)	
400kV SAMI-DEHGAM CKT-2	29-Nov-23	0:08:00	29-Nov-23	10:00:00	0:00:00	0:00:00	0:00:00	9:52:00	400KV SAMI-DEHGAM LINE- 2 manually discharged against code no WR/3541 at 00:08 hrs. on 29.11.2023 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/3590)	
400kV MUNDRA-SAMI CKT-2	29-Nov-23	0:15:00	29-Nov-23	10:04:00	0:00:00	0:00:00	0:00:00	9:49:00	400KV SAMI-MUNDRA LINE- 2 manually discharged against code no WR/3542 at 00:15 hrs. on 29.11.2023 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/3589)	
400kV SAMI-DEHGAM CKT-2	1-Dec-23	0:12:00	1-Dec-23	7:36:00	0:00:00	0:00:00	7:24:00	0:00:00	400KV SAMI-DEHGAM LINE- 2 manually discharged against code no WR/3849 at 00:12 hrs. on 01.12.2023 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/22)	99.79
400kV MUNDRA-SAMI CKT-2	1-Dec-23	0:17:00	1-Dec-23	7:54:00	0:00:00	0:00:00	7:37:00	0:00:00	400KV SAMI-MUNDRA LINE- 2 manually discharged against code no WR/3851 at 00:17 hrs. on 01.12.2023 as per instruction received from ALDC for bus voltage control. (Charging Code: WR/21)	
400kV MUNDRA-SAMI CKT-1	19-Dec-23	8:23:00	19-Dec-23	20:00:00	11:37:00	0:00:00	0:00:00	0:00:00	400KV SAMI-MUNDRA LINE- 2 discharged against code no WR/2418 at 08:23 hrs for Annual Maintenance & Testing of 400KV-APL-MUNDRA-SAMI-1 Line equipments. (Permission for charging mail sent 19:30 Hrs and code received 20:20 hrs and line charged 20:28 hrs aginst Charging Code: WR/2543 )	
400kV MUNDRA-SAMI CKT-1	27-Dec-23	11:13:00	27-Dec-23	11:45:00	0:32:00	0:00:00	0:00:00	0:00:00	400KV-APL-MUNDRA-SAMI-1 discharged at 11:13 hrs against code WR/3539 for Annual Maintenance & Testing of Line Reactor-1. (After Sami Mundra line-1 charged without reactor against same code.)	
400kV MUNDRA-SAMI CKT-1	27-Dec-23	20:42:00	27-Dec-23	20:50:00	0:08:00	0:00:00	0:00:00	0:00:00	400KV-APL-MUNDRA-SAMI-1 discharged at 20:42 hrs against code WR/3605 for taking Line Reactor-1 in service. (400KV-APL-MUNDRA-SAMI-1 Line taken into service with Line reactor-1 against same code).	99.79
400kV MUNDRA-SAMI CKT-1	5-Feb-24	9:43:00	5-Feb-24	10:00:00	0:17:00	0:00:00	0:00:00	0:00:00	400KV-APL-MUNDRA-SAMI-1 discharged at 09:43 hrs on date 05.02.2024 against code WR/514 for Overhauling Work of Line Reactor-1. ( Sami Mundra line-1 charged without reactor at 10:00 on date 05.02.2024 against code WR/514 )	
400kV MUNDRA-SAMI CKT-1	6-Feb-24	1:26:00	6-Feb-24	8:36:00	0:00:00	0:00:00	0:00:00	7:10:00	400KV APL-Mundra-Sami line-1 manually discharged at 01:26 hrs on dt.06.02.2024, against code no WR/605 for voltage regulation. ( Sami Mundra line-1 Charged at 08:36 without reactor against Code no WR/617 on date 6.02.2024)	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
400kV MUNDRA-SAMI CKT-2	7-Feb-24	3:45:00	7-Feb-24	8:09:00	0:00:00	0:00:00	0:00:00	4:24:00	400KV APL-Mundra-Sami line-2 discharged at 03:45 hrs on dt.07.02.2024, against code no WR/739 for voltage regulation. ( Sami Mundra line-2 Charged at 08:09 on date 7.02.2024 against Code no WR/754 )	98.55
400kV MUNDRA-SAMI CKT-1	7-Feb-24	10:05:00	10-Feb-24	15:18:00	77:13:00	0:00:00	0:00:00	0:00:00	400KV APL Mundra -SAMI line-1 discharged at 10:05 hrs on date 07.02.2024 against code No WR/787 for 10-CTB R,Y,B phase CT (Line Metering CT) replacement work at Mundra end . (LCP returned and Ready to charge intimation given to Mundra end from Sami end at 16:38Hrs on dated 08.02.2024 but line charged at 15:18 on dated 10.02.2024 due to CEA approval issue from Mundra end ) 400KV APL-Sami Mundra line-1 charged at 15:18 on date 10.02.2024 against code: WR/1287.	
400kV MUNDRA-SAMI CKT-1	15-Feb-24	15:19:00	15-Feb-24	15:33:00	0:14:00	0:00:00	0:00:00	0:00:00	400Kv MUNDRA-SAMI I discharged at 15:19 hrs on dated 15.02.2024 against code:1908 for Line reactor-1 taken in to service. 400Kv MUNDRA-SAMI I charged at 15:33 hrs on dated 15.02.2024 against code WR/1910 after Overhauling Work completed.	

II

**Elements where restoration time has exceeded the standards specified in Regulation 5 (b)**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL



III

**Details of compensation paid by the inter-State transmission licensee**

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5 (b)		Compensation paid (in Rs.)
	% Availability rescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL