

Element wise Outage Details of Adani Transmission (India) Limited (Asset 1 HVAC) for FY 2023 - 24

| Element Name | Outage | | Restoration | | Duration of Outage Attributable to | | | | | | % Availability |
|--|-----------|----------|-------------|----------|------------------------------------|----------|--|------------------|---|--------|----------------|
| | Date | Time | Date | Time | Inter-State Transmission LICENCE | OTHERS | System constraint/ Natural calamity/ Militancy | DEEMED AVAILABLE | Reason of Outage | | |
| 400kV Mohindergarh (ATIL) - Dhanonda (HVPNL) Ckt-1 | 21-Jun-23 | 17:24:00 | 21-Jun-23 | 21:38:00 | 4:14:00 | 0:00:00 | 0:00:00 | 0:00:00 | Dhanonda(HVPNL)-Mohindergarh(Adani) ckt-1 tripped due to lightning strike failure of series reactor R-Ph occurred then charged back at 21:38 Hrs. & Readiness time is 20:07 Hrs. | 99.951 | |
| 400kV Mohindergarh (ATIL) - Dhanonda (HVPNL) Ckt-1 | 24-Jul-23 | 20:50:00 | 25-Jul-23 | 7:00:00 | 0:00:00 | 10:10:00 | 0:00:00 | 0:00:00 | Dhanonda Ckt-1 tripped due to DT Received from Dhanonda s/s end (Direct Trip Receive CH-2). As per telephonic conversation line was hand tripped due to some issue in Line isolator of Nimrana line at their end. | 100 | |
| 400kV Mohindergarh (ATIL) - Dhanonda (HVPNL) Ckt-1 | 23-Aug-23 | 1:34:00 | 23-Aug-23 | 7:29:00 | 0:00:00 | 5:55:00 | 0:00:00 | 0:00:00 | Shutdown taken by HVPNL 400 kV Dhanonda SS for R phase isolator of Tie Bay maintenance work at their end. | 100 | |
| 400kV Mohindergarh (ATIL) - Dhanonda (HVPNL) Ckt-2 | 21-Sep-23 | 11:03:00 | 21-Sep-23 | 19:32:00 | 0:00:00 | 8:29:00 | 0:00:00 | 0:00:00 | Shutdown has been taken from Neemrana end for Defects rectification work of nature defect. After clearance received from Neemrana end Dhanonda(HVPNL)-Mohindergarh(Adani) ckt-2 was charged | 100 | |
| 400kV Mohindergarh (ATIL) - Dhanonda (HVPNL) Ckt-1 | 23-Sep-23 | 10:34:00 | 23-Sep-23 | 18:22:00 | 0:00:00 | 7:48:00 | 0:00:00 | 0:00:00 | Shutdown has been taken from Neemrana end for Defects rectification work. After clearance received from Neemrana end Dhanonda(HVPNL)-Mohindergarh(Adani) ckt-1 was charged | | |
| 400kV Mohindergarh (ATIL) - Bhiwani (PG) Ckt-1 | 21-Jan-23 | 8:39:00 | 21-Jan-23 | 20:43:00 | 0:00:00 | 12:04:00 | 0:00:00 | 0:00:00 | Outage approved by RLDC (RQ120451) for line crossing work by NRSS36. | 100 | |
| 400kV Mohindergarh (ATIL) - Bhiwani (PG) Ckt-2 | 21-Jan-23 | 8:40:00 | 21-Jan-23 | 20:44:00 | 0:00:00 | 12:04:00 | 0:00:00 | 0:00:00 | Outage approved by RLDC (RQ120452) for line crossing work by NRSS36. | | |
| 400kV Mohindergarh (ATIL) - Bhiwani (PG) Ckt-1 | 6-Oct-23 | 10:22:00 | 6-Oct-23 | 19:48:00 | 9:26:00 | 0:00:00 | 0:00:00 | 0:00:00 | 400kV Mohindergarh (ATIL) - Bhiwani (PG) Ckt-1 Planned outage taken for Annual Maintenance and Bay equipment Testing. | | |

| Element Name | Outage | | Restoration | | Duration of Outage Attributable to | | | | | | % Availability |
|---|-----------|----------|-------------|----------|------------------------------------|---------|--|-------------------|--|--------|----------------|
| | Date | Time | Date | Time | Inter-State Transmission LICENCE | OTHERS | System constraint/ Natural calamity/ Militancy | DEEMED AVAILAB LE | Reason of Outage | | |
| 400kV Mohinderg arh (ATIL) - Bhiwani (PG) Ckt-2 | 7-Oct-23 | 9:33:00 | 7-Oct-23 | 20:25:00 | 10:52:00 | 0:00:00 | 0:00:00 | 0:00:00 | 400KV Mohindergarh (ATIL) - Bhiwani (PG) Ckt-2 Planned outage taken for Annual Maintenance and Bay equipment Testing. | 98.863 | |
| 400kV Mohinderg arh (ATIL) - Dhanonda (HVPNL) Ckt-1 | 9-Oct-23 | 11:45:00 | 9-Oct-23 | 15:59:00 | 0:00:00 | 4:14:00 | 0:00:00 | 0:00:00 | Emergency shutdown has been taken from Dhanonda end for hotspot rectification work in their Tie Bay Isolator. After clearance received from Dhanonda end, 400 KV Mohindergarh(APL)-Dhanonda (HVPNL) Ckt-1 was charged. | | |
| 400kV Mohinderg arh (ATIL) - Dhanonda (HVPNL) Ckt-1 | 3-Nov-23 | 2:46:00 | 3-Nov-23 | 11:58:00 | 0:00:00 | 9:12:00 | 0:00:00 | 0:00:00 | 400 KV Mohindergarh(APL)-Dhanonda(HVPNL) Ckt-1 tripped due to Tie bay isolator burnout at Dhanonda Substation (Direct Trip received). After clearance received from Dhanonda Substation line was charged | 100 | |
| 400kV Mohinderg arh (ATIL) - Dhanonda (HVPNL) Ckt-1 | 7-Nov-23 | 14:18:00 | 7-Nov-23 | 17:17:00 | 0:00:00 | 0:00:00 | 0:00:00 | 2:59:00 | Shutdown taken for 400 KV Mohindergarh(APL)-Dhanonda(HVPNL) Ckt-1 by Dhanonda S/s to attend the hotspot on B-phase Tie bay isolator at Dhanonda Substation. After clearance received from Dhanonda Substation line was charged | | |
| 400kV Mohinderg arh (ATIL) - Bhiwani (PG) Ckt-1 | 15-Nov-23 | 2:51:00 | 16-Nov-23 | 9:26:00 | 0:00:00 | 0:00:00 | 0:00:00 | 30:35:00 | As per grid requirement & for grid voltage regulation 400 KV Mohindergarh(APL)-Biwani-(PG) Ckt-1 shutdown was given and after as per requirement from NRLDC line was charged | | |
| 400kV Mohinderg arh (ATIL) - Bhiwani (PG) Ckt-1 | 19-Nov-23 | 23:13:00 | 20-Nov-23 | 7:54:00 | 0:00:00 | 0:00:00 | 0:00:00 | 8:41:00 | As per grid requirement & for grid voltage regulation 400 KV Mohindergarh(APL)-Biwani-(PG) Ckt-1 shutdown was given and after as per requirement from NRLDC line was charged | | |
| 400kV Mohinderg arh (ATIL) - Bhiwani (PG) Ckt-1 | 11-Dec-23 | 0:16:00 | 12-Dec-23 | 7:44:00 | 0:00:00 | 0:00:00 | 0:00:00 | 31:28:00 | As per grid requirement & instruction from NRLDC, 400 KV Mohindergarh(APL)-Bhiwani(PG) Ckt-1 shutdown was taken for grid voltage regulation and after code received, Line was charged. | 100 | |
| 400kV Mohinderg arh (ATIL) - Bhiwani (PG) Ckt-2 | 11-Dec-23 | 0:19:00 | 12-Dec-23 | 7:43:00 | 0:00:00 | 0:00:00 | 0:00:00 | 31:24:00 | As per grid requirement & instruction from NRLDC, 400 KV Mohindergarh(APL)-Bhiwani(PG) Ckt-2 shutdown was taken for grid voltage regulation and after code received, Line was charged. | | |

| Element Name | Outage | | Restoration | | Duration of Outage Attributable to | | | | | | |
|--|-----------|----------|-------------|----------|------------------------------------|---------|--|------------------|--|----------------|--|
| | Date | Time | Date | Time | Inter-State Transmission LICENCE | OTHERS | System constraint/ Natural calamity/ Militancy | DEEMED AVAILABLE | Reason of Outage | % Availability | |
| 400kV Mohindergarh (ATIL) - Dhanonda (HVPNL) Ckt-1 | 20-Feb-24 | 14:24:00 | 20-Feb-24 | 16:19:00 | 0:00:00 | 0:00:00 | 0:00:00 | 1:55:00 | 400KV Mahendragarh To Dhaonda ckt-1 Emergency shutdwon taken for isolator Hotspots attending work from Dhanoda S/S End. | 100 | |
| 400kV Mohindergarh (ATIL) - Dhanonda (HVPNL) Ckt-1 | 31-Mar-24 | 13:22:00 | 31-Mar-24 | 23:59:00 | 10:37:00 | 0:00:00 | 0:00:00 | 0:00:00 | 400kV Mohindergarh (ATIL) - Dhanonda (HVPNL) Ckt-1 Outage taken for attending Oil leakage from Line CVT (T5) at Mahendragarh terminal till 23:59 hrs on 31.03.2024 | 99.881 | |

II

Elements where restoration time has exceeded the standards specified in Regulation 5 (b)

| Element Name | Restoration time as specified in Regulation 5 (b) (in days) | Actual restoration time (in days) |
|--------------|--|--------------------------------------|
| NIL | NIL | NIL |
| NIL | NIL | NIL |
| NIL | NIL | NIL |

III

Details of compensation paid by the inter-State transmission licensee

| Element Name | Violation of Regulation 5 (a) | | Violation of Regulation 5 (b) | | Compensation paid (in Rs.) |
|-----------------|----------------------------------|--------------------------|--|--------------------------------------|-------------------------------|
| | % Availability rescribed | Actual % Availability | Restoration time prescribed (in days) | Actual restoration time (in days) | |
| NIL | NIL | NIL | NIL | NIL | NIL |
| NIL | NIL | NIL | NIL | NIL | NIL |
| NIL | NIL | NIL | NIL | NIL | NIL |