

Element wise Outage Details of Sipat Transmission Limited for FY 2023 - 24

Element Name	Outage		Restoration		Duration of Outage Attributable to					
	Date	Time	Date	Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available	Reason of Outage	% Availability
					Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
765KV BILASPUR (PS) - RAJNANDGAON CKT-2	14-Apr-2023	10:16:27	14-Apr-2023	17:35:00	7:18:33	0:00:00	0:00:00	0:00:00	765KV BILASPUR PS - RAJNANDGAON CKT-2 Outage was taken at 10:16:27 hrs. (Outage Code WR-1643, NL-1506) on 14/04/2023 by STL for Line Annual Maintenance and Defect Rectification Work, Restoration and readiness mail sent to WRLDC on 14/04/2023 at 17:05 (Charging Code received WR-1673, NL- 1540) Charged at 18:14:35.	99.63
765KV BILASPUR (PS) - RAJNANDGAON CKT-2	14-Apr-2023	17:35:00	14-Apr-2023	18:14:00	0:00:00	0:39:00	0:00:00	0:00:00	765KV BILASPUR PS - RAJNANDGAON CKT-2 Outage was taken at 10:16:27 hrs. (Outage Code WR-1643, NL-1506) on 14/04/2023 by STL for Line Annual Maintenance and Defect Rectification Work, Restoration and readiness mail sent to WRLDC on 14/04/2023 at 17:05 (Charging Code received WR-1673, NL- 1540) Charged at 18:14:35.	
765KV BILASPUR (PS) - RAJNANDGAON CKT-1	12-May-2023	10:24:40	12-May-2023	17:11:00	6:46:20	0:00:00	0:00:00	0:00:00	765KV BILASPUR PS - RAJNANDGAON CKT-1 Outage was taken at 10:24:40 hrs. (Outage Code WR-1191, NL-1034) on 12/05/2023 by STL Line Team for Annual Maintenance for Defect Rectification Work, Restoration and readiness mail sent to WRLDC on 12/05/2023 at 16:41 (Charging Code received WR-1233, NL- 1079) Charged at 17:11:33.	100
765KV SIPAT - BILASPUR (PS) LINE-3	7-Aug-2023	9:54:00	9-Aug-2023	19:39:00	57:45:00	0:00:00	0:00:00	0:00:00	For Testing of Line CT, CVT LA, Isolators, PM of MB's , tightness checking, Alignment checking,Relay testing	99.98
765KV BILASPUR (PS) - RAJNANDGAON CKT-2	21-Sep-2023	18:38:33	21-Sep-2023	18:38:33	0:00:00	0:00:00	0:00:00	0:00:00	AR Successfully operated on R-Phase. Fault Type: L1-N Fault Location: 106.9kms Fault Current: IR- 6.789KA	99.94
765KV SIPAT - BILASPUR (PS) LINE-3	19-Dec-2023	8:13:00	19-Dec-2023	15:55:00	7:42:00	#####	#####	7:42:00	765KV-SIPAT-BILASPUR-3 Outage was taken at 08:13 hrs. (Outage Code WR-2309, NL-2417) on 19/12/2023 by STL Line Team for Annual Maintenance. Restoration and readiness mail sent to WRLDC on 19/12/2023 at 15:24 (Charging Code received WR-2488, NL- 2384) Charged at 15:55.	100
765KV BILASPUR (PS) - RAJNANDGAON CKT-2	18-Mar-2024	19:05:01	18-Mar-2024	19:05:01	00:00:00	0:00:00	#####	0:00:00	AR Successfully operated on R-Phase. Fault Type: L1-N Fault Location: 87.1 kms Fault Current: 06.8KA	99.35

II

Elements where restoration time has exceeded the standards specified in Regulation 5 (b)

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III

Details of compensation paid by the inter-State transmission licensee

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5 (b)		Compensation paid (in Rs.)
	% Availability rescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL