

Element wise Outage Details of Chattisgarh WR Transmission Limited for FY 2021 - 22

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV Sasan UMPP – Vindhyachal Pooling Station Line	10-04-2021 21:41	11-04-2021 00:11	0:00	2:30	0:00	0:00	Emergency outage taken for Hotspot attending on R- ph line Isolator at PGCIL end. WRLDC Code: 1005/1014 NLDC Code: 604/608.	100
400kV Bus Reactor at Morena SS	11-04-2021 19:27	18-04-2021 13:53	0:00	0:00	0:00	162:26	For Voltage regulation manually discharged Discharging Code- WR-1064 Charging Code- WR-1679	100
765kV - LILO - Padge - Pune (GIS) Ckt-1	28-04-2021 17:47	30-04-2021 23:59	0:00	0:00	0:00	54:12	Manually Opened due to high voltage at Pune (GIS)WRLDC Code:04/2482 . NLDC Code: 04/1371.	100
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	01-06-2021 00:00	19-06-2021 12:33	0:00	0:00	0:00	444:33	For Voltage regulation manually discharged WRLDC Code:05/2183, 06/1812. NLDC Code: 05/960, 06/1082.	100
400kV Bus Reactor at Morena SS	01-06-2021 22:54	12-06-2021 08:01	0:00	0:00	0:00	249:07	For Voltage regulation manually discharged Discharging Code- WR-91 Charging Code- WR-1090	100
400kV Bus Reactor at Morena SS	16-06-2021 22:45	30-06-2021 23:59	0:00	0:00	0:00	337:14	For Voltage regulation manually discharged Discharging Code- WR-1519	
765kV - LILO - Padge - Pune (GIS) Ckt-1	26-06-2021 03:39	29-06-2021 07:57	0:00	0:00	0:00	76:18	For Voltage regulation manually discharged WRLDC Code: 06/2509, 06/2799 , NLDC codes:06/1469, 06/1675	100
765kV - LILO - Padge - Pune (GIS) Ckt-1	29-06-2021 23:08	30-06-2021 10:05	0:00	0:00	0:00	10:57	For Voltage regulation manually discharged WRLDC Code: 06/2887, 06/2919. NLDC Code: 06/1715, 06/1728.	
400kV Bus Reactor at Morena SS	01-07-2021 00:00	11-07-2021 16:55	0:00	0:00	0:00	256:55	For Voltage regulation manually discharged Discharging Code- WR-1519	100
400kV Bus Reactor at Morena SS	11-07-2021 21:01	27-07-2021 13:10	0:00	0:00	0:00	376:09	For Voltage regulation manually discharged Discharging Code- WR-1090 Charging Code- WR-2477	
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station CKT-4	04-07-2021 17:45	04-07-2021 20:32	0:00	0:00	2:47	0:00	Distance Protection, B-Phase to E/F, 2.5 Kms from Vindhyanchal (PS). Charging code - WR-358	100
765kV - LILO - Padge - Pune (GIS) Ckt-1	27-07-2021 20:18	31-07-2021 23:59	0:00	0:00	0:00	99:41	For Voltage regulation manually discharged WRLDC Code:07/2518. NLDC Code: 07/1452.	100
765kV - LILO - Padge - Pune (GIS) Ckt-1	01-08-2021 00:00	23-08-2021 07:40	0:00	0:00	0:00	535:40	For Voltage regulation manually discharged WRLDC Code:07/2518, 08/2230. NLDC Code: 07/1452, 08/1304.	100
765kV - LILO - Padge - Pune (GIS) Ckt-1	23-08-2021 23:13	01-09-2021 00:00	0:00	0:00	0:00	192:47	For Voltage regulation manually discharged WRLDC Code:08/2321. NLDC Code: 08/1349.	
400kV Bus Reactor at Morena SS	07-08-2021 10:42	31-08-2021 15:36	0:00	0:00	0:00	580:54	For Voltage regulation manually discharged Discharging Code- WR-679 Charging Code- WR-3207	100
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station CKT-4	26-08-2021 11:13	26-08-2021 16:11	0:00	4:58	0:00	0:00	Line outage taken by Vindhyachal PGCIL for carrying out Line Bay Equipment maintenance work. (Bay is under PGCIL Scope) Discharging Code- WR-2608<Charging Code- WR-2627	100
400kV Bus Reactor at Morena SS	02-09-2021 17:00	03-09-2021 18:43	0:00	0:00	0:00	25:43	Manually Opened as per LD requirement for Grid Voltage Regulation Discharging Code- WR-201 Charging Code- WR-334	100

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400kV Gwalior - Morena SS Ckt-2	29-09-2021 15:05	29-09-2021 15:05	0:00	0:00	0:00	0:00	Auto Recloser Successfully operated in R-Phase of Ckt-2, 13.4 Kms from Morena SS.	100
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station Ckt-3	03-09-2021 19:05	03-09-2021 19:05	0:00	0:00	0:00	0:00	Auto Recloser Successfully operated in B-phase of Ckt-3, 11.8 Kms NTPC Vindhyachal.	99.86
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station Ckt-3	04-09-2021 18:09	04-09-2021 19:09	1:00	0:00	0:00	0:00	Line tripped due to tripping of tie bay while checking main bay. Main bay was already out due to MB checking.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	01-09-2021 00:00	07-09-2021 13:28	0:00	0:00	0:00	157:28	Manually Opened due to high voltage. WRLDC Code:08/2321 09/734. NLDC Code: 08/1349, 09/287.	100
765kV - LILO - Padge - Pune (GIS) Ckt-1	07-09-2021 22:00	09-09-2021 11:32	0:00	0:00	0:00	37:32	Manually Opened due to high voltage. WRLDC Code:09/800, 09/1013. NLDC Code: 09/318, 09/414.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	11-09-2021 19:13	27-09-2021 11:04	0:00	0:00	0:00	375:51	Manually Opened due to high voltage. WRLDC Code:09/1296, 09/3126. NLDC Code: 09/583, 09/1607.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	30-09-2021 21:34	01-10-2021 00:00	0:00	0:00	0:00	2:26	Manually Opened due to high voltage. WRLDC Code:09/3549. NLDC Code: 09/1861.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	01-10-2021 00:00	08-10-2021 03:38	0:00	0:00	0:00	171:38	For Voltage regulation manually discharged WRLDC Code:09/3549, 10/961. NLDC Code: 09/1861, 10/477.	100
765kV - LILO - Padge - Pune (GIS) Ckt-1	08-10-2021 23:49	10-10-2021 10:12	0:00	0:00	0:00	34:23	For Voltage regulation manually discharged WRLDC Code:10/1130, 10/1310. NLDC Code: 10/535, 10/612.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	11-10-2021 00:40	11-10-2021 10:16	0:00	0:00	0:00	9:36	For Voltage regulation manually discharged WRLDC Code:10/1366, 10/1412. NLDC Code: 10/659, 10/674.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	12-10-2021 00:35	12-10-2021 14:55	0:00	0:00	0:00	14:20	For Voltage regulation manually discharged WRLDC Code:10/1565, 10/1655. NLDC Code: 10/714, 10/748.	
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station Ckt-4	30-10-2021 10:40	30-10-2021 13:00	2:20	0:00	0:00	0:00	Emergency outage of line taken for attending hot-spot in 410-89A -R- phase Isolator. Discharging code-WR-4066 Charging Code-WR-4093	99.69
765kV - LILO - Padge - Pune (GIS) Ckt-1	04-11-2021 17:42	06-11-2021 10:46	0:00	0:00	0:00	41:04	For Voltage regulation manually discharged WRLDC Code:11/356, 11/521. NLDC Code: 11/253, 11/358.	100
400kV Bus Reactor at Morena SS	08-11-2021 07:34	09-11-2021 20:13	0:00	0:00	0:00	36:39	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code - WR - 661 Charging code - WR - 978	100
400kV Bus Reactor at Morena SS	17-11-2021 08:12	19-11-2021 21:53	0:00	0:00	0:00	61:41	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code - WR - 2145 Charging code - WR - 2597	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	23-11-2021 12:19	30-11-2021 23:59	0:00	0:00	0:00	179:40	Line opened to control line loadings on 400KV Pune-Kaiwa line & 400KV Pune-Kharghar line. WRLDC Code:11/3090. NLDC Code: 11/1919	100
400kV Bus Reactor at Morena SS	02-12-2021 08:52	02-12-2021 21:04	0:00	0:00	0:00	12:12	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR-201 Charging code- WR-292	
400kV Bus Reactor at Morena SS	06-12-2021 09:14	07-12-2021 20:58	0:00	0:00	0:00	35:44	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR-800 Charging code- WR-1118	

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400kV Bus Reactor at Morena SS	09-12-2021 09:22	12-12-2021 21:23	0:00	0:00	0:00	84:01	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR-1396 Charging code- WR-1978	100
400kV Bus Reactor at Morena SS	13-12-2021 08:07	13-12-2021 20:49	0:00	0:00	0:00	12:42	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR-2020 Charging code- WR-2152	
400kV Bus Reactor at Morena SS	15-12-2021 10:24	20-12-2021 00:05	0:00	0:00	0:00	109:41	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR-2465 Charging code- WR-3265	
400kV Bus Reactor at Morena SS	20-12-2021 10:27	27-12-2021 00:02	0:00	0:00	0:00	157:35	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR-3364 Charging code- WR-4458	
400kV Bus Reactor at Morena SS	31-12-2021 09:27	31-12-2021 23:59	0:00	0:00	0:00	14:32	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR-5167	
400kV Gwalior - Morena SS Ckt-1	20-12-2021 09:08	20-12-2021 17:36	8:28	0:00	0:00	0:00	Line outage taken for annual maintenance work. Discharging code- WR- 3311 Charging code- WR- 3405	98.86
400kV Gwalior - Morena SS Ckt-2	21-12-2021 08:44	21-12-2021 15:44	7:00	0:00	0:00	0:00	Line outage taken for annual maintenance work. Discharging code- WR-3350 Charging code- WR- 3606	99.06
765kV - LILO - Padge - Pune (GIS) Ckt-1	02-12-2021 01:15	02-12-2021 09:09	0:00	0:00	0:00	7:54	For Voltage regulation manually discharged. WRLDC Code: 12/163, 12/194. NLDC Code: 12/140, 12/118.	100
765kV - LILO - Padge - Pune (GIS) Ckt-1	03-12-2021 00:13	03-12-2021 06:49	0:00	0:00	0:00	6:36	For Voltage regulation manually discharged. WRLDC Code: 12/311, 12/320. NLDC Code: 12/223, 12/232.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	03-12-2021 21:54	08-12-2021 09:09	0:00	0:00	0:00	107:15	For Voltage regulation manually discharged. WRLDC Code: 12/457, 12/1175. NLDC Code: 12/345, 12/859.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	09-12-2021 22:33	10-12-2021 07:03	0:00	0:00	0:00	8:30	For Voltage regulation manually discharged. WRLDC Code: 12/1522, 12/1545. NLDC Code: 12/1121, 12/1132.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	10-12-2021 19:52	29-12-2021 06:13	0:00	0:00	0:00	442:21	For Voltage regulation manually discharged. WRLDC Code: 12/1693, 12/4819. NLDC Code: 12/1241, 12/3523.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	30-12-2021 22:16	31-12-2021 23:59	0:00	0:00	0:00	25:43	For Voltage regulation manually discharged. WRLDC Code: 12/5112. NLDC Code: 12/3740.	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	01-12-2021 00:00	01-12-2021 08:56	0:00	0:00	0:00	8:56	Line opened to control line loadings on 400KV Pune-Kaiwa line & 400KV Pune-Kharghar line. WRLDC Code:11/3090, 12/22, NLDC Code: 11/1919,12/23.	100
765kV Raigarh (Korta) - Champa (Pool) Line	05-12-2021 09:35	05-12-2021 20:19	10:44	0:00	0:00	0:00	Line outage taken to carryout the Insulator replacement work. Discharging Code- WR- 668 & NL- 509 Charging Code- WR-719, NL-556	98.56

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV Champa (Pool) - Dharamjaygarh Line	14-12-2021 08:12	14-12-2021 16:29	8:17	0:00	0:00	0:00	Line outage taken for annual maintenance of line equipment. Readiness given at 15:59 Hrs. Mail attached. Additionally 30 Min considered in Licensee's account. From 16:30 Hrs to till charging time 19:04 Hrs , it is considered deemed available. Discharging Code- WR - 2199, NLDC- 1654 Charging Code- WR-2300 & NLDC-1725	98.89
765kV Champa (Pool) - Dharamjaygarh Line	14-12-2021 16:30	14-12-2021 19:04	0:00	0:00	0:00	2:34		
400kV Bus Reactor at Morena SS	01-01-2022 00:00	02-01-2022 00:07	0:00	0:00	0:00	24:07	For regulation Grid volatge Charging code- WR-102.	100
400kV Bus Reactor at Morena SS	16-01-2022 08:54	21-01-2022 02:00	0:00	0:00	0:00	113:06	For regulation Grid volatge Charging code- WR-3093. code- WR- 2246 Discharging	
400/220kV ICT-2 at Morena SS	12-01-2022 10:15	12-01-2022 11:34	1:19	0:00	0:00	0:00	400/220kV ICT-2 at Morena SS tripped due bus differential protection operated in 220kv side. Charging code- WR-1748	99.82
765kV - LILO - Padge - Pune (GIS) Ckt-1	05-01-2022 23:55	08-01-2022 10:10	0:00	0:00	0:00	58:15	MOHV/Manually opened due to High Voltage. WRLDC Code: 01/728, 01/1129. NLDC Code: 01/502,01/751.	100
765kV - LILO - Padge - Pune (GIS) Ckt-1	11-01-2022 22:59	12-01-2022 08:37	0:00	0:00	0:00	9:38	MOHV/Manually opened due to High Voltage. WRLDC Code: 01/1655,01/1685. NLDC Code: 01/1090, 01/1114.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	12-01-2022 21:19	13-01-2022 10:28	0:00	0:00	0:00	13:09	MOHV/Manually opened due to High Voltage. WRLDC Code: 01/1842, 01/1916. NLDC Code: 01/1198, 01/1253.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	13-01-2022 21:17	15-01-2022 10:34	0:00	0:00	0:00	37:17	MOHV/Manually opened due to High Voltage. WRLDC Code: 01/1998, 01/2155. NLDC Code: 01/1309, 01/1453.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	15-01-2022 23:20	16-01-2022 08:55	0:00	0:00	0:00	9:35	MOHV/Manually opened due to High Voltage. WRLDC Code: 01/2219, 01/2241 . NLDC Code: 01/1510, 01/1531 .	
765kV - LILO - Padge - Pune (GIS) Ckt-1	17-01-2022 21:18	24-01-2022 14:53	0:00	0:00	0:00	161:35	MOHV/Manually opened due to High Voltage. WRLDC Code:01/2536, 01/3623 . NLDC Code: 01/1699, 01/2413.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	25-01-2022 13:54	26-01-2022 11:30	0:00	0:00	0:00	21:36	To control loading of 765/400KV ICT-1 at Padghe SS for its outage. WRLDC Code: 01/3802, 01/3910. NLDC Code: 01/2540, 01/2621.	
765kV - LILO - Padge - Pune (GIS) Ckt-1	26-01-2022 16:56	01-02-2022 00:00	0:00	0:00	0:00	127:04	MOHV/Manually opened due to High Voltage. WRLDC Code: 01/3929. NLDC Code: 01/2641 .	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	01-01-2022 00:00	05-01-2022 10:44	0:00	0:00	0:00	106:44	MOHV/Manually opened due to High Voltage. WRLDC Code: 12/5112, 01/607. NLDC Code: 12/3740,01/432.	100
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	27-01-2022 02:26	27-01-2022 08:25	0:00	0:00	0:00	5:59	To control hogh voltage at Kharghar & Kalwa, LR to be converted to BR at both ends/ Manually opened due to high voltage. WRLDC Code:01/3955, 01/3966 . NLDC Code: 01/2665, 01/2678.	

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV Raigarh (Korta) - Champa (Pool) Line	07-01-2022 10:30	07-01-2022 19:10	8:40	0:00	0:00	0:00	To carryout the Insulator replacement work. Discharging Code- WR- 945 & NL- 647 Charging Code- WR-1035, NL- 689	98.84
400 KV D/C (Quad) Vindhyachal Pooling Station - Vindhyachal Stage (IV) NTPC line - CKT-4	03-02-2022 20:54	03-02-2022 20:54	0:00	0:00	0:00	0:00	AR successfully operated. B ph - E/F, 15.4 Kms from Vindhyachal SS.	100
400 KV D/C (Quad) Vindhyachal Pooling Station - Vindhyachal Stage (IV) NTPC line - CKT-4	27-02-2022 15:04	27-02-2022 15:04	0:00	0:00	0:00	0:00	AR successfully operated. B ph - E/F, 14 Kms from Vindhyachal SS.	
400kV Bus Reactor at Morena	04-02-2022 11:10	06-02-2022 00:40	0:00	0:00	0:00	37:30	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR- 541 Charging Code- WR- 806	100
400kV Bus Reactor at Morena	16-02-2022 06:01	20-02-2022 23:14	0:00	0:00	0:00	113:13	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR- 2345 Charging Code- WR- 3029	
400kV Bus Reactor at Morena	21-02-2022 09:57	21-02-2022 21:40	0:00	0:00	0:00	11:43	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR- 3082 Charging Code- WR- 3200	
400kV Bus Reactor at Morena	24-02-2022 06:08	28-02-2022 00:00	0:00	0:00	0:00	89:52	Manually Opened as per LD requirement for Grid Voltage Regulation. Discharging code- WR- 3580.	
765kV - LILO - Pune (GIS) - Padge Ckt-1	01-02-2022 00:00	09-02-2022 09:46	0:00	0:00	0:00	201:46	For Voltage regulation manually discharged. Line discharged on 26th Jan 16:56 hrs. Outage hours considered from 1st Feb 00:00 Hrs. WRLDC Code: 01/3929,02/1265. NLDC Code: 01/2641,02/1032 .	100
765kV - LILO - Pune (GIS) - Padge Ckt-1	09-02-2022 19:25	10-02-2022 06:56	0:00	0:00	0:00	11:31	For Voltage regulation manually discharged. WRLDC Code: 02/1369, 02/1400. NLDC Code: 02/1084,02/1114.	
765kV - LILO - Pune (GIS) - Padge Ckt-1	10-02-2022 21:49	11-02-2022 09:34	0:00	0:00	0:00	11:45	For Voltage regulation manually discharged. WRLDC Code: 02/1559,02/1613. NLDC Code: 02/1217, 02/1245.	
400kV Bus Reactor at Morena SS	01-03-2022 00:00	31-03-2022 23:59	0:00	0:00	0:00	743:59	Manually Opened on 24-02-2022 as per LD requirement for Grid Voltage Regulation. Outage Hrs considered till 31-03-2022. Discharging code- WR- 3580	100
765kV Sasan UMPP – Vindhyachal Pooling Station Line	11-03-2022 10:34	11-03-2022 19:31	0:00	8:57	0:00	0:00	Line outage taken by PGCIL Vindhyachal for line bay equipment maintenance and to attend 713-89B isolator problem. Discharging code- WRLDC-1322, NLDC-823 Charging ode-WRLDC-1382,NLDC-858	100
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	12-03-2022 19:40	22-03-2022 11:00	0:00	0:00	0:00	231:20	For Voltage regulation manually discharged. Charging code (03/2764, 03/1619) issued on 11:00 Hrs 22-03-2022 but due to delay in charging by RTAMC Nagpur, code cancelled and converted in to forced outage. Line finally charged on 23-03-2022 12:10 Hrs.	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	22-03-2022 11:00	22-03-2022 12:42	0:00	1:42	0:00	0:00		

Discharging code : WRLDC Code: 03/4530, NLDC Code:

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	22-03-2022 12:42	23-03-2022 12:10	0:00	0:00	0:00	23:28	Discharging Code : WRLDC Code: 03/1529, NLDC Code: 03/953 Charging Code: WRLDC 03/2942. NLDC 03/1699.	100
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	23-03-2022 13:07	23-03-2022 15:11	0:00	2:04	0:00	0:00	Line tripped on Y-E fault 144kms from Pune SS. CWRTL portion is upto 64KM from Pune end. WRLDC Charging Code: 03/2949. NLDC Charging Code: 03/1700.	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	23-03-2022 15:14	23-03-2022 21:49	0:00	6:35	0:00	0:00	Line Hand tripped by site due to sparking observed in isolator at PGCIL Aurangabad SS. WRLDC Charging Code: 03/3006. NLDC Charging Code: 03/1747.	

II

Elements where restoration time has exceeded the standards specified in Regulation 5 (b)

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III

Details of compensation paid by the inter-State transmission licensee

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5 (b)		Compensation paid (in Rs.)
	% Availability rescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL