

Element wise Outage Details of Warora-Kurnool Transmission Limited for FY 2021 - 22

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV 240 MVAR Line Reactor-2 of Rajnandgaon - Warora Ckt-2 at Warora SS	19-04-2021 10:09	19-04-2021 19:44	9:34	0:00	0:00	0:00	Outage of 765kV 240 MVAR Line Reactor-2 taken for annual maintenance works. Discharging Code : WR- 1744 & NL- 975 Charging Code : WR- 1783 & NL- 988	98.67%
765kV 240 MVAR Line Reactor-1 of Rajnandgaon - Warora Ckt-1 at Warora SS	13-08-2021 11:01	13-08-2021 13:44	2:43	0:00	0:00	0:00	765kV 240 MVAR Line Reactor-1 of Rajnandgaon - Warora Ckt-1 tripped on Backup impedance protection at Warora SS. Charging code : WR-1364, NL-700	99.48%
765kV 240 MVAR Line Reactor-1 of Rajnandgaon - Warora Ckt-1 at Warora SS	19-08-2021 09:47	19-08-2021 10:54	1:07	0:00	0:00	0:00	765kV 240 MVAR Line Reactor-1 of Rajnandgaon - Warora Ckt-1 for replacement of Voltage selection Relay at Warora SS. Discharging code : WR-1933, NL-1088, 765KV Charging code : WR-1945, NL-1104, 765KV	100.00%
765kV 240 MVAR Line Reactor-1 of Rajnandgaon - Warora Ckt-1 at Warora SS	15-12-2021 10:37	15-12-2021 21:18	0:00	10:41	0:00	0:00	Outage was taken by PGCIL Warora SS for Line bay AMP and relay testing work at 765kV WARORA SS end. NBFC returned at 21:18 Hrs. As per the instruction of WRLDC, Line was not Charged due to overvoltage. Line charged at 06:09 Hrs on 16th Dec. Discharging code - WR- 2452 & NL- 1808 Charging code - WR- 2573 & NL- 1887	100.00%
765kV 240 MVAR Line Reactor-1 of Rajnandgaon - Warora Ckt-1 at Warora SS	15-12-2021 21:18	16-12-2021 06:09	0:00	0:00	0:00	8:51	Outage was taken by PGCIL Warora SS for Line bay AMP and relay testing work at 765kV WARORA SS end. NBFC returned at 21:18 Hrs. As per the instruction of WRLDC, Line was not Charged due to overvoltage. Line charged at 06:09 Hrs on 16th Dec. Discharging code - WR- 2452 & NL- 1808 Charging code - WR- 2573 & NL- 1887	100.00%
765kV 240 MVAR Line Reactor-1 of Rajnandgaon - Warora Ckt-1 at Warora SS	22-12-2021 11:41	22-12-2021 17:02	0:00	0:00	0:00	5:21	Outage was taken by WKTL-ADANI for CSD Commissioning in line reactor breaker at 765kV WARORA SS end.Outage Proposed as a deemed available as per 475th OCC meeting discussion. MoM attached herewith.	100.00%
765kV 240 MVAR Line Reactor-2 of Rajnandgaon - Warora Ckt-2 at Warora SS	29-12-2021 10:48	29-12-2021 17:41	0:00	0:00	0:00	6:53	Outage was taken by WKTL-ADANI for CSD Commissioning in line reactor breaker at 765kV WARORA SS end. Outage Proposed as a deemed available as per 475th OCC meeting discussion. MoM attached herewith.	100.00%
765kV 240 MVAR Line Reactor-2 of Rajnandgaon - Warora Ckt-2 at Warora SS	09-03-2022 11:12	09-03-2022 22:27	0:00	11:15	0:00	0:00	Line outage was taken by PGCIL-Warora SS for line bay equipment AMP and Relay testing works at Warora SS. Discharging code - WR- 1019 & NL- 666 Charging code - WR-1110 & NL-710	100.00%

II

Elements where restoration time has exceeded the standards specified in Regulation 5 (b)

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III

Details of compensation paid by the inter-State transmission licensee

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5 (b)		Compensation paid (in Rs.)
	% Availability rescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL