

Element wise Outage Details of Warora-Kurnool Transmission Limited for FY 2022 - 23

Element Name	Outage		Restoration		Duration of Outage Attributable to					
	Date	Time	Date	Time	Inter-State Transmission LICENCEE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILAB LE	Reason of Outage	% Availability
765kV 240 MVAR Line Reactor-1 of Rajnandgaon - Warora Ckt-1 at Warora SS	30-Dec-22	9:21:00	31-Dec-22	20:37:00	0:00:00	35:16:00	0:00:00	0:00:00	765KV-RAJNANDGAON-RRWTL-WARORA -2 Outage was taken by RRWTL for OPGW repairing work. Line reactor made off along with line.	100

II

Elements where restoration time has exceeded the standards specified in Regulation 5 (b)

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III

Details of compensation paid by the inter-State transmission licensee

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5 (b)		Compensation paid (in Rs.)
	% Availability rescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL