

Element wise Outage Details of Chattisgarh WR Transmission Limited for FY 2023 - 24

Element Name	Outage		Restoration		Duration of Outage Attributable to						% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage		
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Apr-23	0:00:00	3-Apr-23	7:10:00	0:00:00	0:00:00	55:10:00	0:00:00	To control loading on Pune Connected lines. WRLDC Opening Code-2/3265 NLDC Opening Code-2/2992, WRLDC charging code-4/185, NLDC Charging Code-4/225	100	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	3-Apr-23	21:14:00	26-Apr-23	21:22:00	0:00:00	0:00:00	552:08:00	0:00:00	MOHV/Manually opened due to High Voltage. WRLDC Opening Code-4/294 NLDC Opening Code-4/334, WRLDC charging code-4/2974, NLDC Charging Code-4/2840		
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station Ckt-2	13-Apr-23	10:36:00	13-Apr-23	19:08:00	0:00:00	8:32:00	0:00:00	0:00:00	For line terminal annual maintenance work taken by PGCIL. Discharging code-WR-1511 Charging Code-WR-1576		
765kV Champa (Pool) - Dharamjaygarh Line	22-Apr-23	10:09:00	22-Apr-23	18:34:00	0:00:00	8:25:00	0:00:00	0:00:00	For line terminal annual maintenance work taken by PGCIL. Discharging code- WRLDC-2530 Charging Code-2459		
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	27-Apr-23	5:39:00	30-Apr-23	11:59:00	0:00:00	0:00:00	78:20:00	0:00:00	To control loading on 400kV-Pune-Chakan and 400kV-Pune-Pune ckt. WRLDC Opening Code- 4/ 2999 NLDC Opening Code-4/2856 WRLDC charging code-4/, NLDC Charging Code-4/		
765kV Champa (Pool) - Dharamjaygarh Line	1-May-23	0:00:00	12-May-23	14:43:00	0:00:00	0:00:00	278:43:00	0:00:00	To control loading on 400kV-Pune-Chakan and 400kV-Pune-Pune ckt. WRLDC Opening Code- 4/ 2999 NLDC Opening Code-4/2856 WRLDC charging code-5/1211, NLDC Charging Code-5/1061		
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	12-May-23	22:10:00	19-May-23	16:58:00	0:00:00	0:00:00	162:48:00	0:00:00	Open for controlling loading on 400 kV Pune-Pune lines WRLDC Opening Code- 5/1293 NLDC Opening Code-5/1127 WRLDC charging code-5/2058, NLDC Charging Code-5/1927		

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	20-May-23	8:55:00	24-May-23	16:47:00	0:00:00	0:00:00	103:52:00	0:00:00	To control loading on 400kV-Pune-Chakan and 400kV-Pune-Pune ckt. WRLDC Opening Code- 5/2133 NLDC Opening Code-5/1991 WRLDC charging code-5/2600, NLDC Charging Code-5/2489	100
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	24-May-23	23:11:00	31-May-23	11:59:00	0:00:00	0:00:00	156:48:00	0:00:00	To control loading on 400 kV Pune- chakan and convert L/R as B/R at both ends. WRLDC Opening Code- 5/2647, NLDC Opening Code-5/2423, WRLDC charging code-5/, NLDC Charging Code-5/	
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station Ckt-2	26-May-23	12:04:00	26-May-23	12:04:00	0:00:00	0:00:00	0:00:00	0:00:00	A/R Successfull in Y-phase. Fault distance M1- 10.0KM, M2 - 10.9KM . Fault Current- M1-20.5Kamp , M2- 17.2Kamp.	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Jun-23	0:00:00	17-Jun-23	7:28:00	0:00:00	0:00:00	391:28:00	0:00:00	To control loading on 400 kV Pune- chakan and convert L/R as B/R at both ends. WRLDC Opening Code- 5/2647, NLDC Opening Code-5/2423, WRLDC charging code-6/1970, NLDC Charging Code-6/1805	
765kV Raigarh (Korta) - Champa (Pool) Line	4-Jun-23	15:21:00	4-Jun-23	22:45:00	0:00:00	7:24:00	0:00:00	0:00:00	Line tripping due to PGCIL end disturbances.	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	17-Jun-23	20:10:00	21-Jun-23	11:39:00	0:00:00	0:00:00	87:29:00	0:00:00	To control loading on 400 kV Pune- chakan and convert L/R as B/R at both ends. WRLDC Opening Code- 6/ 2063 NLDC Opening Code-6/1880 WRLDC charging code-6/2382, NLDC Charging Code-6/2268	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	22-Jun-23	8:22:00	23-Jun-23	9:23:00	0:00:00	0:00:00	25:01:00	0:00:00	To control loading on 400 kV Pune- chakan and convert L/R as B/R at both ends. WRLDC Opening Code- 6/ 2450 NLDC Opening Code-6/2356 WRLDC charging code-6/2573, NLDC Charging Code-6/2469	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
765kV Champa (Pool) - Dharamjaygarh Line	23-Jun-23	11:39:00	23-Jun-23	19:25:00	0:00:00	7:46:00	0:00:00	0:00:00	Line outage taken by PGCIL for Annual maintenance work. Dishcharging code- NLDC- 2501 ,WRLDC- 2597 Charging Code-NLDC- 2545, WRLDC - 2626.	99.64
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	23-Jun-23	21:41:00	27-Jun-23	9:49:00	0:00:00	0:00:00	84:08:00	0:00:00	To control voltage and loadings. Both ends Line reactors to be in service as Bus Reactors. /Voltage Regulation WRLDC Opening Code- 6/2643 NLDC Opening Code-6/2562 WRLDC charging code-6/2987, NLDC Charging Code-6/2910	
765kV - LILO - Padge - Pune (GIS) Ckt-1	26-Jun-23	11:14:00	26-Jun-23	19:53:00	8:39:00	0:00:00	0:00:00	0:00:00	Outage taken for Replacement of faulty insulators. WRLDC Opening Code- 6/2880 NLDC Opening Code-6/2823 WRLDC charging code-6/2929, NLDC Charging Code-6/2853	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	27-Jun-23	18:39:00	27-Jun-23	20:36:00	0:00:00	1:57:00	0:00:00	0:00:00	After completion of work, returned the outage at 18:09 hrs. already half an hour is considered for the code process in Licensee But the line was charged at 20:36hr. Charging of line was delayed due to charging of line reactor. There was a delay of 02:27 hr.	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	27-Jun-23	9:49:00	27-Jun-23	18:39:00	8:50:00	0:00:00	0:00:00	0:00:00	Outage taken for Replacement of faulty insulators. WRLDC Opening Code- 6/2985 NLDC Opening Code-6/2912 WRLDC charging code-6/3036, NLDC Charging Code-6/2967	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	28-Jun-23	7:59:00	30-Jun-23	23:59:00	0:00:00	0:00:00	64:00:00	0:00:00	To control voltage and loadings. Both ends Line reactors to be in service as Bus Reactors. /Voltage Regulation WRLDC Opening Code- 6/ 3073 NLDC Opening Code-6/3010 WRLDC charging code-6/, NLDC Charging Code-6/	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Jul-23	0:00:00	21-Jul-23	2:31:00	0:00:00	0:00:00	482:31:00	0:00:00	To control voltage and loadings. Both ends Line reactors to be in service as Bus Reactors. /Voltage Regulation WRLDC Opening Code- 6/ 3073 NLDC Opening Code-6/3010 WRLDC charging code-7/1807, NLDC Charging Code-7/1744	100
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	22-Jul-23	17:15:00	26-Jul-23	6:55:00	0:00:00	0:00:00	85:40:00	0:00:00	Open to control loadings on pune connected lines and convert L/r as B/R at both ends. WRLDC Opening Code- 7/1979 NLDC Opening Code-7/1893 WRLDC charging code-7/2285, NLDC Charging Code-7/2209	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCEE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	29-Jul-23	0:16:00	31-Jul-23	23:59:00	0:00:00	0:00:00	71:43:00	0:00:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 7/2544 NLDC Opening Code-7/2436 WRLDC charging code-7/, NLDC Charging Code-7/	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Aug-23	0:00:00	31-Aug-23	23:59:00	0:00:00	0:00:00	743:59:00	0:00:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 7/2544 NLDC Opening Code-7/2436 WRLDC charging code-7/, NLDC Charging Code-7/	99.86
400kV Gwalior - Morena SS Ckt-1	3-Aug-23	10:37:00	3-Aug-23	13:09:00	2:32:00	0:00:00	0:00:00	0:00:00	Outage taken for line bay maintenance work. Readiness mail has been sent at 12:39 Hrs. on 03.08.2023 .Already 30 minutes is added in the scope of Licensee for code process. Line was charged at 13:26 Hrs. on 03.08.2023. Discharging Code- WR-171 Charging Code- WR-186	
400kV Gwalior - Morena SS Ckt-2	4-Aug-23	11:02:00	4-Aug-23	13:13:00	2:11:00	0:00:00	0:00:00	0:00:00	Outage taken for line bay maintenance work. Discharging Code- WR-171 Charging Code- WR-186	
765kV Champa (Pool) - Dharamjaygarh Line	7-Aug-23	17:52:00	7-Aug-23	19:59:00	0:00:00	2:07:00	0:00:00	0:00:00	765KV Dharamjaygarh-Champa Ckt#2 Line tripped at 17:52hrs at Champa end only due to DT receipt from Dharamjaygarh end (line charged from Dharamjaygarh end). Protection schemes were checked at Dharamjaygarh end and no abnormalities were found. line Synchronized at Champa end. Charging Code- WR-498/597	
400kV Bus Reactor at Morena SS	19-Aug-23	10:53:00	19-Aug-23	13:31:00	2:38:00	0:00:00	0:00:00	0:00:00	Outage taken for Annual Maintenance Work. Discharging Code- WR-1596 Charging Code- WR-1607	
400/220kV ICT-1 at Morena SS	22-Aug-23	10:25:00	22-Aug-23	13:28:00	3:03:00	0:00:00	0:00:00	0:00:00	Outage taken for Annual Maintenance Work. Discharging Code- WR-1829 Charging Code- WR-1846	
400/220kV ICT-2 at Morena SS	23-Aug-23	11:08:00	23-Aug-23	13:26:00	2:18:00	0:00:00	0:00:00	0:00:00	Outage taken for Annual Maintenance Work. Readiness mail has been sent at 12:31 Hrs. on 23.08.2023 .Already 30 minutes is added in the scope of Licensee for code process. Line was charged at 13:26 Hrs. on 23.08.2023. Discharging Code- WR-1938 Charging Code- WR-1946	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Sep-23	0:00:00	22-Sep-23	7:12:00	0:00:00	0:00:00	0:00:00	511:12:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 7/2544 NLDC Opening Code-7/2436 WRLDC charging code-9/2131, NLDC Charging Code-9/1971	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
400kV Bus Reactor at Morena SS	4-Sep-23	11:39:00	16-Sep-23	14:51:00	0:00:00	0:00:00	0:00:00	291:12:00	For Grid Voltage regulation Discharging code- WR - 336 Charging Code- WR - 1569	100
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	22-Sep-23	14:02:00	28-Sep-23	8:21:00	0:00:00	0:00:00	0:00:00	138:19:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 9/ 2173 NLDC Opening Code-9/2007 WRLDC charging code-7/2734, NLDC Charging Code-7/2503	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	28-Sep-23	20:46:00	30-Sep-23	7:51:00	0:00:00	0:00:00	0:00:00	35:05:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 9/2802 NLDC Opening Code-9/2555 WRLDC charging code-9/2901, NLDC Charging Code-9/2648	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	30-Sep-23	20:08:00	30-Sep-23	23:59:00	0:00:00	0:00:00	0:00:00	3:51:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 9/2981, NLDC Opening Code-9/2718, WRLDC charging code-, NLDC Charging Code-	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Jan-23	0:00:00	10-Jan-23	4:59:00	0:00:00	0:00:00	0:00:00	220:59:00	To control loading on pune connected lines and convert L/R as B/r at both ends WRLDC Opening Code- 12/4428 NLDC Opening Code-12/4835, WRLDC charging code-1/1189, NLDC Charging Code-1/1656	
765kV - LILO - Padge - Pune (GIS) Ckt-1	11-Jan-23	6:25:00	11-Jan-23	18:59:00	0:00:00	12:34:00	0:00:00	0:00:00	ESD taken by PGCIL to attend Polymer insulator in Y-phase found broken at Loc No. 589. WRLDC Opening Code- 1/ 1367NLDC Opening Code-1/1858, WRLDC charging code-1/1480, NLDC Charging Code-1/2021	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	11-Jan-23	21:58:00	16-Jan-23	9:20:00	0:00:00	0:00:00	0:00:00	107:22:00	Voltage Regulation. SLR to be converted as B/R/Voltage Regulation WRLDC Opening Code- 1/1507 NLDC Opening Code-1/2041, WRLDC charging code-1/2107, NLDC Charging Code-1/2806	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	16-Jan-23	18:29:00	24-Jan-23	10:22:00	0:00:00	0:00:00	0:00:00	183:53:00	To control loading on Pune connected lines and convert L/R as B/r at both ends WRLDC Opening Code- 1/2222 NLDC Opening Code-1/2929, WRLDC charging code-1/3389, NLDC Charging Code-1/4253	
400kV Gwalior - Morena SS Ckt-2	25-Jan-23	7:29:00	25-Jan-23	7:29:00	0:00:00	0:00:00	0:00:00	0:00:00	Auto reclose successful at Morena SS end but CB tripped at Gwalior (PGCIL) end and line was charged at no load. Ss.Line was synchronised at 12:40hrs from PGCIL end.	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	25-Jan-23	12:44:00	30-Jan-23	8:25:00	0:00:00	0:00:00	0:00:00	115:41:00	To control loading on Pune connected lines and convert L/R as B/r at both ends WRLDC Opening Code- 1/3576 NLDC Opening Code-1/4478, WRLDC charging code-1/4123, NLDC Charging Code-1/5144	99.67
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	31-Jan-23	7:13:00	31-Jan-23	23:59:00	0:00:00	0:00:00	0:00:00	16:46:00	To control loading on 400 kV Pune-Chakan & 400 kV Pune-GIS-Pune-PG 4 ckts WRLDC Opening Code- 1/4248 NLDC Opening Code-1/5285, WRLDC charging code-1/, NLDC Charging Code-1/	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Oct-23	0:00:00	31-Oct-23	23:59:00	0:00:00	0:00:00	0:00:00	743:59:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 9/2981, NLDC Opening Code-9/2718, WRLDC charging code-, NLDC Charging Code-	100
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Nov-23	0:00:00	30-Nov-23	12:49:00	0:00:00	0:00:00	708:49:00	0:00:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 9/2981, NLDC Opening Code-9/2718, WRLDC charging code-11/3766, NLDC Charging Code-11/3069	99.8
400kV Gwalior - Morena SS Ckt-2	4-Nov-23	5:22:00	4-Nov-23	21:53:00	0:00:00	16:31:00	0:00:00	0:00:00	Tripping occurred due to disturbance occurred in PGCIL end GIS Bay. Pgcil has taken time to check their GIS bay for charging clearance. Mail Attached. M1-37.9(KM),M1-1.59 kA M2-16.5(KM) M2-3.76 kA Zone-1 operated Charging Code- WR-487	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	30-Nov-23	20:26:00	30-Nov-23	23:59:00	0:00:00	0:00:00	3:33:00	0:00:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 11/3824, NLDC Opening Code-11/ 3114	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Dec-23	0:00:00	31-Dec-23	23:59:00	0:00:00	0:00:00	743:59:00	0:00:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 11/3824, NLDC Opening Code-11/ 3114	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
400kV Gwalior - Morena SS Ckt-2	14-Dec-23	4:43:00	14-Dec-23	23:34:00	0:00:00	0:00:00	0:00:00	18:51:00	The charging clearance given by Morena at 04:43 Hrs. on 14.12.2023 but Pgcil_Gwalior has taken time to check their GIS bay for charging clearance. Mail Attached. Due to this charging was delayed due to PGCIL. Charging Code- WR-1845	99.88
400kV Gwalior - Morena SS Ckt-2	14-Dec-23	3:05:00	14-Dec-23	4:43:00	1:38:00	0:00:00	0:00:00	0:00:00	Line tripped due fault in Y-N. M1-48.0(KM),M1-1.73 kA M2-20.8(KM) M2-3.80 kA Zone-1 operated	
765kV Sasan UMPP - Vindhyachal Pooling Station Line	20-Dec-23	9:28:00	20-Dec-23	18:43:00	9:15:00	0:00:00	0:00:00	0:00:00	For annual Maintenance works of line. Discharging code-WR-2597,NLDC-2484 Charging code-WR-2682, NLDC-2574	
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station Ckt-3	21-Dec-23	9:50:00	21-Dec-23	18:03:00	8:13:00	0:00:00	0:00:00	0:00:00	For annual Maintenance works of line & the readiness mail has been sent 17:33 Hrs. But line was charged at 18:32 Hrs. But for the code process we had considered the extra 30 minutes in the Licensee Account. Discharging code-WR-2782 Charging code-WR-2860	
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station Ckt-4	22-Dec-23	10:45:00	22-Dec-23	18:35:00	7:50:00	0:00:00	0:00:00	0:00:00	For annual Maintenance works of line. Discharging code-WR-2937 Charging code-WR-3034	
400kV Bus Reactor at Morena SS	31-Dec-23	11:03:00	31-Dec-23	23:59:00	0:00:00	0:00:00	12:56:00	0:00:00	For Grid Voltage regulation. Discharging Code-WR-4046	99.88
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Feb-24	0:00:00	4-Feb-24	9:31:00	0:00:00	0:00:00	81:31:00	0:00:00	765kV - LILO - Pune (GIS) - Arungabad Ckt-2 Manually out to convert L/R as B/R/ to control the High Voltage. WRLDC Opening Code- 1/4073, NLDC Opening Code-1/4238 & WRLDC Charging Code:02/402,NLDC Charging code:430	

Element Name	Outage		Restoration		Duration of Outage Attributable to					% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	4-Feb-24	13:04:00	29-Feb-24	23:59:00	0:00:00	0:00:00	610:55:00	0:00:00	765kV - LILO - Pune (GIS) - Arungabad Ckt-2 Manually Out to convert L/R as B/R/Manually to control the High Voltage. WRLDC Opening Code- 2/426, NLDC Opening Code-2/461	99.83
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station Ckt-2	13-Feb-24	8:57:00	13-Feb-24	8:57:00	0:00:00	0:00:00	0:00:00	0:00:00	400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station Ckt-3 Autoreclosure successful operated in Y-N Phase. M1-1.8Kms, 19.88KA.	
400 kV Pune(GIS)-Aurangabad-I	14-Feb-24	0:00:00	28-Mar-24	10:23:00	0:00:00	0:00:00	384:00:00	0:00:00	400 kV Pune(GIS)-Aurangabad-I Manually To control loading on 400 kV Pune-Chakan.WRLDC Opening code:2/1701 WRLDC Charging Code:03/3168	
400kV Gwalior - Morena SS Ckt-1	15-Feb-24	10:13:00	15-Feb-24	17:58:00	7:45:00	0:00:00	0:00:00	0:00:00	400kV Gwalior - Morena SS Ckt-1 Outage was taken by TL team for AMP work and Jumper replacement work of line. Readiness has been sent at 17:28 Hrs. but line was charged at 18:19 Hrs.So the duration considered in the account of licensee as per readiness time and additional 30 minutes for code process. Discharging Code- WR-1871 Charging Code- WR-1933	
400kV Gwalior - Morena SS Ckt-2	16-Feb-24	12:18:00	16-Feb-24	21:19:00	9:01:00	0:00:00	0:00:00	0:00:00	400kV Gwalior - Morena SS Ckt-2 Outage was taken by TL team for AMP work. Discharging Code- WR-2022 Charging Code- WR-2096	
765kV - LILO - Pune (GIS) - Arungabad Ckt-2	1-Mar-24	0:00:00	31-Mar-24	23:59:00	0:00:00	0:00:00	743:59:00	0:00:00	MOHV and to convert L/R as B/R/Manually opened due to High Voltage. WRLDC Opening Code- 2/426, NLDC Opening Code-2/461	100
400kV Vindhyachal Stage (IV) NTPC line - Vindhyachal Pooling Station Ckt-1	30-Mar-24	21:06:00	30-Mar-24	21:28:00	0:00:00	0:22:00	0:00:00	0:00:00	AT Pgcil vindhyachal pooling station, B-ph LA was blast due to 400 KV Vindhyachal Pooling Station - Vindhyachal Stage (IV) NTPC line-1 got tripped and due to that our Circuit -4 is also connected at same bus at NTPC Vindhyachal end, So, Circuit breaker opened at NTPC end only. Our line was charged from PGCIL VPS end. Charging Code- WR-3504	

II

Elements where restoration time has exceeded the standards specified in Regulation 5 (b)

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III

Details of compensation paid by the inter-State transmission licensee

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5 (b)		Compensation paid (in Rs.)
	% Availability rescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL