

Element wise Outage Details of Karur Transmission Limited for FY 2023 - 24

Element Name	Outage		Restoration		Duration of Outage Attributable to						% Availability
	Date	Time	Date	Time	Inter-State Transmission LICENCE	OTHERS	System constraint/ Natural calamity/ Militancy	DEEMED AVAILABLE	Reason of Outage		
125 MVAR 420kV Bus reactor-1 at Karur	19-Jan-24	10:05:00	21-Jan-24	14:15:00	0:00:00	0:00:00	0:00:00	52:10:00	AS per LD instruction BR-1 Discharged for voltage regulation.Discharge code:-3078 Charge code:-3408		100
125 MVAR 420kV Bus reactor-2 at Karur	20-Jan-24	8:54:00	21-Jan-24	14:48:00	0:00:00	0:00:00	0:00:00	29:54:00	AS per LD instruction BR-2 Discharged for voltage regulation.Discharge code:-3244 Charge code:-3409		
125 MVAR 420kV Bus reactor-1 at Karur	8-Feb-24	11:21:00	13-Feb-24	18:13:00	0:00:00	0:00:00	126:52:00	0:00:00	AS per LD instruction BR-1 Discharged for voltage regulation.Discharge code:-1527 Charge code:-2589		100
125 MVAR 420kV Bus reactor-2 at Karur	8-Feb-24	11:24:00	13-Feb-24	18:16:00	0:00:00	0:00:00	126:52:00	0:00:00	AS per LD instruction BR-1 Discharged for voltage regulation.Discharge code:-1528 Charge code:-2590		
125 MVAR 420kV Bus reactor-1 at Karur	16-Feb-24	9:44:00	22-Feb-24	18:32:00	0:00:00	0:00:00	152:48:00	0:00:00	AS per LD instruction BR-1 Discharged for voltage regulation.Discharge code:-3079 Charge code:-4324		
125 MVAR 420kV Bus reactor-2 at Karur	16-Feb-24	9:46:00	29-Feb-24	0:00:00	0:00:00	0:00:00	302:14:00	0:00:00	AS per LD instruction BR-1 Discharged for voltage regulation.Discharge code:-3080		
125 MVAR 420kV Bus reactor-1 at Karur	23-Feb-24	9:33:00	29-Feb-24	0:00:00	0:00:00	0:00:00	134:27:00	0:00:00	AS per LD instruction BR-1 Discharged for voltage regulation.Discharge code:-4423		

II

Elements where restoration time has exceeded the standards specified in Regulation 5 (b)

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III

Details of compensation paid by the inter-State transmission licensee

Element Name	Violation of Regulation 5 (a)		Violation of Regulation 5 (b)		Compensation paid (in Rs.)
	% Availability rescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL