

Information to be submitted by Transmission Licensee to the Commission - PPP-10 TPTSL

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of April 2024

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.0000	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.0000	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Apr-24	100
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Apr-24	0	0.0

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6	Violation of Regulation 8	Compensation Paid (in Rs)
	% Availability Prescribed	Restoration time as per Regulation (in days)	
NIL	NIL	NIL	NIL
Total			

Jeet

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of May 2024

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.0000	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.0000	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	May-24	100
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
May-24	0	0.00

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	Compensation Paid (in Rs)
NIL	NIL	NIL	NIL	NIL	NIL
Total					

[Signature]

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of June 2024

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.0000	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.0000	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Jun-24	100
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Jun-24	0	0.0

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	Compensation Paid (in Rs)
NIL	NIL	NIL	NIL	NIL	NIL
Total					

Handwritten signature

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of July- 2024

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.0000	
Power Transformer/ Inter connecting Transformer (ICT) Reactors	0	0	100.0000	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Jul-24	100
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Jul-24	0	0.00

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	Compensation Paid (in Rs)
NIL	NIL	NIL	NIL	NIL	NIL
Total					

[Signature]

Information to be submitted by Transmission Licensee to the Commission - PPP-10 TPTSL

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of August- 2024

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.0000	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.0000	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Aug-24	100
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Aug-24	0	0.00

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	% Availability Prescribed	Violation of Regulation 6	Restoration time as per Regulation 8	Actual Restoration time (in days)	Compensation Paid (in Rs)
NIL	NIL	NIL	NIL	NIL	NIL
Total					

Forced

Information to be submitted by Transmission Licensee to the Commission - PPP-10 TPTSL

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of September- 2024

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.0000	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.0000	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	
Note - Total Outage time shall be summation of outage time of all elements during the month				

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Sep-24	100
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Sep-24	0	0.00

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6		Violation of Regulation 8	
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)
NIL	NIL	NIL	NIL	NIL
Total				
				NIL

Handwritten signature

SAIFI & SAIDI of M/S Thar Power Transmission Service Limited (TPTSL) for the Year 2024-25 (April 24 to Sep 24)

132 kV

Sr. No.	Month	Line		Transformer		Total Interruption		Total No. of GSS	SAIFI	SAIDI
		Freq. of tripping	Duration of tripping	Freq. of tripping	Duration of tripping	Freq. of tripping	Duration of tripping			
1	Apr-24	0	0	0	0	0	0	5	0.00	0.00
2	May-24	0	0	0	0	0	0	5	0.00	0.00
3	Jun-24	0	0	0	0	0	0	5	0.00	0.00
4	Jul-24	0	0	0	0	0	0	5	0.00	0.00
5	Aug-24	0	0	0	0	0	0	5	0.00	0.00
6	Sep-24	0	0	0	0	0	0	5	0.00	0.00

May

AEN (SOLD)

Patidar

KAMAL PATIDAR
Superintending Engineer (SOLD)
RVPN, Heerapura, Jaipur



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

[Corporate Identity Number (CIN): U40109RJ2000SGC016485]
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

RVPN
An ISO 9001:2015
Certified Company

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)
SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403
E-mail: se.sold@rvpn.co.in website: [www.http://energy.rajasthan.gov.in/rvpngl](http://energy.rajasthan.gov.in/rvpngl)

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D. 139

Dated:- 07.05.2024

The Superintending Engineer (Billing),
RUVNL, Jaipur

Sub:- Certification of Transmission System Availability of Thar Power Transmission Service Limited (TPTSL) under RAJ/PPP-10, for the month April' 2024.

Ref:- Letter No. TPTSL/SLDC/02052024/01 Dated 02.05.2024 of M/s TPTSL.

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month April' 2024 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

Accordingly, the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month April' 2024 are certified provisionally as under:-

Availability of AC lines	100.00 %
Availability of Power Transformers / ICTs	100.00 %
Total transmission system availability	100.00 %

This is for your kind information and further necessary action please.

(Sona Shishodia)
Superintending Engineer (SOLD)
RRVNL, Jaipur

Copy forwarded to the Thar Power Transmission Service Limited (TPTSL), 31(A), 6th Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganer Road, Jaipur-302019, Rajasthan.

Superintending Engineer (SOLD)
RRVNL, Jaipur

RajKaj Ref
7021153



Signature valid

Digitally signed by Sona Shishodia
Designation: Superintending
Engineer
Date: 2024.05.07 18:15:06 IST
Reason: Approved



RVPN
An ISO 9001:2015
Certified Company

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

[Corporate Identity Number (CIN): U40109RJ2000SGC016485]
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)

SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403
E-mail: se.sold@rvpn.co.in website: [www.http://energy.rajasthan.gov.in/rvpn](http://energy.rajasthan.gov.in/rvpn)

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D. 241

Dated:- 06-06-2024

The Superintending Engineer (Billing),
RUVNL, Jaipur

Sub:- Certification of Transmission System Availability of Thar Power Transmission Service Limited (TPTSL) under RAJ/PPP-10, for the month May' 2024.

Ref:- Letter No. TPTSL/SLDC/03062024/01 Dated 03.06.2024 of M/s TPTSL.

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month May' 2024 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

Accordingly, the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month May' 2024 are certified provisionally as under:-

Availability of AC lines	100.00 %
Availability of Power Transformers / ICTs	100.00 %
Total transmission system availability	100.00 %

This is for your kind information and further necessary action please.

(Sona Shishodia)
Superintending Engineer (SOLD)
RRVNL, Jaipur

Copy forwarded to the Thar Power Transmission Service Limited (TPTSL), 31(A), 6th Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganer Road, Jaipur-302019, Rajasthan.

Superintending Engineer (SOLD)
RRVNL, Jaipur

RajKaj Ref
7839189



Signature valid

Digitally signed by Sona Shishodia
Designation: Superintending
Engineer
Date: 2024.06.06 18:08:46 IST
Reason: Approved



RVPN
An ISO 9001:2015
Certified Company

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

[Corporate Identity Number (CIN): U40109RJ2000SGC016485]
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)

SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403
E-mail: se.sold@rvpn.co.in website: [www.http://energy.rajasthan.gov.in/rvpnl](http://energy.rajasthan.gov.in/rvpnl)

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D.

370

Dated:- 05/07/24

The Superintending Engineer (Billing),
RUVNL, Jaipur

Sub:- Certification of Transmission System Availability of Thar Power Transmission Service Limited (TPTSL) under RAJ/PPP-10, for the month June' 2024.

Ref:- Letter No. TPTSL/SLDC/02072024/01 Dated 02.07.2024 of M/s TPTSL.

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month June' 2024 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

Accordingly, the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month June' 2024 are certified provisionally as under:-

Availability of AC lines	100.00 %
Availability of Power Transformers / ICTs	100.00 %
Total transmission system availability	100.00 %

This is for your kind information and further necessary action please.

(Sona Shishodia)
Superintending Engineer (SOLD)
RRVNL, Jaipur

Copy forwarded to the Thar Power Transmission Service Limited (TPTSL), 31(A), 6th Floor,
Plot No. 5, Swej Farm, Mahima Trinity, New Sanganer Road, Jaipur-302019, Rajasthan.

Superintending Engineer (SOLD)
RRVNL, Jaipur

RajKaj Ref
8659485



Signature valid

Digitally signed by Sona Shishodia
Designation: Superintending
Engineer
Date: 2024.07.05 18:47:43 IST
Reason: Approved



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

[Corporate Identity Number (CIN): U40109RJ2000SGC016486]
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

RRV/PN
An ISO 9001:2015
Certified Company

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)
SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403
E-mail: se.sold@rpn.co.in website: www.http://energy.rajasthan.gov.in/rpn

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D. 509

Dated:- 07.08.2024

The Superintending Engineer (Billing),
RUVNL, Jaipur

Sub:- Certification of Transmission System Availability of Thar Power Transmission Service Limited (TPTSL) under RAJ/PPP-10, for the month July' 2024.

Ref:- Letter No. TPTSL/SLDC/02082024/01 Dated 02.08.2024 of M/s TPTSL.

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month July' 2024 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

Accordingly, the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month July' 2024 are certified provisionally as under:-

Availability of AC lines	100.00 %
Availability of Power Transformers / ICTs	100.00 %
Total transmission system availability	100.00 %

This is for your kind information and further necessary action please.

(Sona Shishodia)
Superintending Engineer (SOLD)
RRV/PN, Jaipur

Copy forwarded to the Thar Power Transmission Service Limited (TPTSL), 31(A), 6th Floor,
Plot No. 5, Swej Farm, Mahima Trinity, New Sanganer Road, Jaipur-302019, Rajasthan.

Superintending Engineer (SOLD)
RRV/PN, Jaipur

RajKaj Ref
9616767



Signature valid

Digitally signed by Sona Shishodia
Designation: Superintending
Engineer
Date: 2024.08.07 12:34:04 IST
Reason: Approved



RVPN
An ISO 9001:2015
Certified Company

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

[Corporate Identity Number (CIN): U40109RJ2000SGC016485]
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)

SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403
E-mail: se.sold@rvpn.co.in website: [www.http://energy.rajasthan.gov.in/rvpn](http://energy.rajasthan.gov.in/rvpn)

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D.

636

Dated:- 05/09/2024

The Superintending Engineer (Billing),
RUVNL, Jaipur

Sub:- Certification of Transmission System Availability of Thar Power Transmission Service Limited (TPTSL) under RAJ/PPP-10, for the month August' 2024.

Ref:- Letter No. TPTSL/SLDC/02092024/01 Dated 02.09.2024 of M/s TPTSL.

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month August' 2024 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

Accordingly, the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month August' 2024 are certified provisionally as under:-

Availability of AC lines	100.00 %
Availability of Power Transformers / ICTs	100.00 %
Total transmission system availability	100.00 %

This is for your kind information and further necessary action please.

(Sona Shishodia)
Superintending Engineer (SOLD)
RRVNL, Jaipur

Copy forwarded to the Thar Power Transmission Service Limited (TPTSL), 31(A), 6th Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganer Road, Jaipur-302019, Rajasthan.

Superintending Engineer (SOLD)
RRVNL, Jaipur

RajKaj Ref
10303120



Signature valid

Digitally signed by Sona Shishodia
Designation: Superintending
Engineer
Date: 2024.09.05 17:19:41 IST
Reason: Approved



RVPN
An ISO 9001:2015
Certified Company

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

[Corporate Identity Number (CIN): U40109RJ2000SGC016485]
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)

SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403
E-mail: se.sold@rvpn.co.in website: [www.http://energy.rajasthan.gov.in/rvpnl](http://energy.rajasthan.gov.in/rvpnl)

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D.

766

Dated:- 08-10-2024

The Superintending Engineer (Billing),
RUVNL, Jaipur

Sub:- Certification of Transmission System Availability of Thar Power Transmission Service Limited (TPTSL) under RAJ/PPP-10, for the month September' 2024.

Ref:- Letter No. TPTSL/SLDC/03102024/01 Dated 03.10.2024 of M/s TPTSL.

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month September' 2024 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

Accordingly, the element wise availability & total transmission system availability of M/s Thar Power Transmission Service Limited (TPTSL) for the month September' 2024 are certified provisionally as under:-

Availability of AC lines	100.00 %
Availability of Power Transformers / ICTs	100.00 %
Total transmission system availability	100.00 %

This is for your kind information and further necessary action please.

(Sona Shishodia)
Superintending Engineer (SOLD)
RRVPNL, Jaipur

Copy forwarded to the Thar Power Transmission Service Limited (TPTSL), 31(A), 6th Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganer Road, Jaipur-302019, Rajasthan.

Superintending Engineer (SOLD)
RRVPNL, Jaipur

RajKaj Ref
10980465



Signature valid

Digitally signed by Sona Shishodia
Designation: Superintending
Engineer
Date: 2024.10.08 12:29:50 IST
Reason: Approved