

Jamnagar Transmission Limited

C 105, Anand Niketan, New Delhi 110021

NOTICE

(UNDER SUB SECTION (2) OF SECTION 15 OF THE ELECTRICITY ACT, 2003)

1. **JAMNAGAR TRANSMISSION LIMITED**, having its Registered Office at **C 105, Anand Niketan, New Delhi 110021**, which is incorporated under the Companies Act, 2013, has made an application before the Central Electricity Regulatory Commission, New Delhi under sub-section (1) of Section 15 of the Electricity Act, 2003 for grant of transmission licence in respect of the transmission lines, sub-stations and other assets, the details of which are given.

Sr. No.	Name of the line/Sub- station (location)	Line Length / Capacity	Estimated Completion Cost or Levelised Transmission Charges	Schedule COD	Remarks
1.	Establishment of 2x1500 MVA 765/400 kV Jamnagar (GIS) PS with 2x330 MVAR 765 kV bus reactor and 2x125 MVAR 420 kV bus reactor.	765kV 400kV	Quoted Annual Transmission Charges – Rs 3917.57 million	24 months from effective date	
2.	Halvad – Jamnagar 765 kV D/c line	147 Km			
3.	2 nos. of 765 kV line bays at Halvad for termination of Halvad – Jamnagar 765 kV D/c line	765kV			
4.	330 MVAR switchable line reactors on each ckt at Jamnagar end of Halvad – Jamnagar 765 kV D/c line (with NGR bypass arrangement)	765kV			
5.	LILO of Jam Khambhaliya PS – Lakadia 400 kV D/c (triple snowbird) line at Jamnagar.	7 Km			
6.	50 MVAR, 420 kV switchable line reactors on each ckt at Jamnagar end of Jamnagar – Lakadia 400kV D/c line (with NGR bypass arrangement)	400kV			
7.	Jamnagar – Jam Khambhaliya 400 kV D/c (Quad ACSR/AAAC/AL59 moose equivalent) line	41 Km			
8.	2 nos. of 400kV line bays at Jam Khambhaliya for termination of Jamnagar – Jam Khambhaliya	400kV			
9.	LILO of CGPL – Jetpur 400kV D/c (triple snowbird) line at Jamnagar.	123 Km			
10.	80MVAR, 420kV switchable line reactors on each ckt at Jamnagar end of Jamnagar – CGPL 400kV D/c line (with NGR bypass arrangement)	400kV			
11.	LILO of both ckts of Kalavad – Bhogat 400kV D/c line (Twin AL-59) at Jam Khambhaliya PS	11 Km			
12.	4 nos. of 400kV line bays at Jam Khambhaliya for LILO of both ckts of Kalavad – Bhogat 400kV D/c line	400kV			
13.	±400 MVAR STATCOM with 3x125 MVAR MSC & 2x125 MVAR MSR at Jamnagar 400kV Bus section	400kV			

2. Complete application and other documents filed before the Commission are available on the website www.adanienergysolutions.com for access by any person. The application can also be inspected at the office of the Company at **4th Floor South Wing, KP Epitome, Makarba, Ahmedabad, 380051** with **Mr. Prashant Kumar** or Office of the Commission in accordance with the procedure specified by the Commission.

3. Objections or suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, **6th, 7th & 8th Floors, Tower B, World Trade Centre, Nauroji Nagar, New Delhi- 110029** (E-mail Id : registry@cercind.gov.in) with a copy of the objection(s)/ suggestion(s) to the applicant or its authorized agent, within 15 days of the publication of the notice in the newspaper.

Place : Ahmedabad

Date : 22.10.2024

Prashant Kumar

(Head - Regulatory & Commercial)