

Mundra I Transmission Limited

C 105, Anand Niketan, New Delhi 110021

NOTICE

(UNDER SUB SECTION (2) OF SECTION 15 OF THE ELECTRICITY ACT, 2003)

1. **MUNDRA I TRANSMISSION LIMITED**, having its Office at **C 105, ANAND NIKETAN, NEW DELHI 110021**, which is incorporated under the Companies Act, 2013, has made an application before the Central Electricity Regulatory Commission, New Delhi under sub-section (1) of Section 15 of the Electricity Act, 2003 for grant of transmission license in respect of the transmission lines, sub-stations and other assets, the details of which are given.

Sl. No.	Name of the line/Sub- station (location)	Line Length / Capacity	Estimated Completion Cost or Levelised Transmission Charges	Schedule COD
1	Augmentation of Transformation capacity at 765/400 kV Navinal (Mundra) S/s (GIS) by 2x1500 MVA ICTs along with 2x330 MVAR, 765 kV and 2x125 MVAR, 420 kV bus reactors on Bus Section-II and 1x125MVAR, 420 kV bus reactor on Bus Section-I. This will involve creation of 765 kV and 400 kV Bus Sections-2 through sectionalization arrangement. The 400 kV and 765 kV Sectionalizer shall be normally closed. - Creation of New 765 kV and 400 kV Bus Section-II 765 kV Sectionalizer – 1 Set 400 kV Sectionalizer – 1 set 765/400 kV, 1500 MVA ICT-2 Nos. (on Sec-II) 765 kV ICT bays- 2 Nos. (on Sec-II) 400 kV ICT bays- 2 Nos. (on Sec-II) 330 MVAR 765 kV bus reactor-2 Nos. (Sec-II) 125 MVAR 420 kV bus reactor-3 Nos. (1 No. on Sec-I and 2 Nos. on Sec-II) 765 kV reactor bay- 2 Nos. (Sec- II) 400 kV reactor bay- 3 Nos. (1 No. on Sec-I and 2 Nos. on Sec- II)	2x1500 MVA	Quoted Annual Transmission Charges – Rs. 3081.73 million	20.03.2028
2	Navinal (Mundra) (GIS) – Bhuj 765 KV D/C Line	73.278 Km		
3	765 kV line bays at each end of Navinal (Mundra) (GIS) – Bhuj 765 kV D/C line 765 kV line bays-2 Nos. (AIS) (for Bhuj end) 765 kV line bays-2 Nos. (GIS) (for Navinal (Mundra) end) (on Sec-II)			
4	±300 MVAR STATCOM along with 2x125 MVAR MSC and 1x125 MVAR MSR at Navinal (Mundra) (GIS) 400 kV Bus section-I. ±300 MVAR STATCOM along with 2x125MVAR MSC and 1x125MVAR MSR 400 kV bay – 1 No.			
5	±300 MVAR STATCOM along with 2x125 MVAR MSC and 1x125 MVAR MSR at Navinal (Mundra) (GIS) 400 kV Bus section-II ±300 MVAR STATCOM along with 2x125 MVAR MSC and 1x125 MVAR MSR 400 kV bay – 1 No.			

2. Complete application and other documents filed before the Commission are available on the website www.adanienergysolutions.com for access by any person. The application can also be inspected at the office of the Company at **4th Floor South Wing, KP Epitome, Makarba, Ahmedabad, 380051** with **Mr. Prashant Kumar** or Office of the Commission in accordance with the procedure specified by the Commission.
3. Objections or suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, **6th, 7th & 8th Floors, Tower B, World Trade Centre, Nauroji Nagar, New Delhi- 110029**, (Email id: registry@cercind.gov.in.) with a copy of the objection(s)/suggestion(s) to the applicant or its authorized agent, within 15 days of the publication of the notice in the newspaper.

Place : Ahmedabad

Date : 29.03.2025

Prashant Kumar
(Head - Regulatory & Commercial)