

Outage details of AC Transmission Line/ Power Transformer/ Static Var Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of April 2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	32	32	99.985	
Power Transformer/ Inter connecting Transformer (CT)	32	32	99.988	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Apr-23	99.99
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Apr-23	0.33	10.67

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6		Violation of Regulation 8		Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL

Permit
22/12/2023

Outage details of AC Transmission Line, Power Transformer/ Static V Ar Compensator/ series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of May 2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	81	81	99.998	
Power Transformer/ Inter connecting Transformer (ICT)	81	81	100.000	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	May-23	99.995
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
May-23	0.33	13.50

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 5		Violation of Regulation 8		Compensation Paid (in RS)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL

Revised
22/12/2023

Outage details: of AC Transmission Line/ Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links) / Line Reactors/ Bus reactors for the month of June 2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.000	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.000	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Jun-23	100.000
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Jun-23	0.00	0

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6		Violation of Regulation 8		Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL

Power
22/06/2023

Outage details of AC Transmission Line/ Power Transformer/ Static V Ar Comp. /sator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus reactors for the month of July 2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.000	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.000	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Jul-23	100.000
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Jul-23	0.00	0

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6		Violation of Regulation 8		Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL

Permit
22/11/2023

Stage details of AC Transmission Line/ Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus Reactors for the month of August 2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	0	0	100.000	
Power Transformer/ Inter connecting Transformer (ICT)	0	0	100.000	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Aug-23	100.000
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Aug-23	0.17	4.67

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 5		Violation of Regulation 8		Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL

Approved
22/12/2023

Outage details of AC Transmission / Line/ Power Transformer/ Static VAR Compensator/ Series Compensator/ HVDC (Back to Back and Bi-Pole Links)/ Line Reactors/ Bus Reactors for the month of September 2023

(I) Element Wise Transmission System availability

Particulars	Total Outage time during month (minutes)	Total outage time during month considered for computation of availability (minutes)	% availability during the month	Remarks, if any
AC Transmission	28	28	99.993	
Power Transformer/ Inter connecting Transformer (ICT)	28	28	100.000	
Reactors	NA	NA	NA	
Static VAR Compensators	NA	NA	NA	
Series Compensator	NA	NA	NA	
HVDC (Back to Back and Bi-Pole Links)	NA	NA	NA	

Note - Total Outage time shall be summation of outage time of all elements during the month

(II) Availability of the AC and HVDC Transmission System

Particular	Year	% Availability
AC Transmission System	Sep-23	99.996
HVDC Transmission System	NA	NA

(III) SAIFI and SAIDI of the Transmission System

Month	SAIFI (in numbers)	SAIDI (in minutes)
Sep-23	0.17	4.67

(IV) Details of Elements where restoration time has exceeded the standards specified in Regulation 8

Element Name	Restoration time as specified in Regulation 8	Actual Restoration Time (in days)
NIL	NIL	NIL

(V) Details of compensation paid by the Transmission Licensee

Element Name	Violation of Regulation 6		Violation of Regulation 8		Compensation Paid (in Rs)
	% Availability Prescribed	Actual % Availability	Restoration time as per Regulation (in days)	Actual Restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
Total	NIL	NIL	NIL	NIL	NIL

Signature
22/11/2023

SAIFI & SAIDI of M/S Barmer Power Transmission Service Limited (BPTSL) for the Year 2023-24 (April 23 to Sept 23)

Sr No.	Month	Line		Transformer		Total Interruption		Total No. of GSS	SAIFI	SAIDI
		Freq. of tripping	Duration of tripping	Freq. of tripping	Duration of tripping	Freq. of tripping	Duration of tripping			
1	Apr-23	1	32	1	32	2	64	6	0.33	10.67
2	May-23	2	81	0	0	2	81	6	0.33	13.50
3	Jun-23	0	0	0	0	0	0	6	0.00	0.00
4	Jul-23	0	0	0	0	0	0	6	0.00	0.00
5	Aug-23	0	0	0	0	0	0	6	0.00	0.00
6	Sep-23	1	28	0	0	1	28	6	0.17	4.67

132 KV

Handwritten signature

Handwritten signature



Digitally signed by Mukul Bhargava
 Designation: Superintending
 Engineer
 Date: 2023.05.05 17:09:52 IST
 Reason: Approved

Signature valid

Superintending Engineer (SOLD)
 RVPNL, Jaipur

Copy forwarded to the M/s Barmer Power Transmission Service Limited (BPTSL) 31(A), 6th Floor, Plot No. 5, Swej Farm, Mahina Trinity, New Sanganeer Road, Jaipur-302019 Rajasthan.

(Mukul Bhargava)
 Superintending Engineer (SOLD)
 RVPNL, Jaipur

This is for your kind information and further necessary action please.

Availability of AC lines	99.985 %
Availability of Power Transformers / ICTs	99.988 %
Total transmission system availability	99.986 %

M/s Barmer Power Transmission Service Limited (BPTSL) for the month April 2023 are certified provisionally as under:-

Accordingly, the element wise availability & total transmission system availability of M/s Barmer Power Transmission Service Limited (BPTSL) for the month April 2023 details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Barmer Power Transmission Service Limited (BPTSL) for the month April 2023 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

Ref :- Letter No. BPTSL/SLDC/02052023/02 Dated 02.05.2023 of M/s BPTSL.

Sub:- Certification of Transmission System Availability of Barmer Power Transmission Service Limited (BPTSL) under RAJ/PP-09, for the month April 2023.


RUVNL, Jaipur

The Superintending Engineer (Billing),

No. RVPN/SE (SOLD)/XEN-1/F. /D.

Dated:-

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)
 SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403
 E-mail: se.sold@rsvpnl.co.in website: www.http://energy.rajasthan.gov.in/rvpnl



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED
 [Corporate Identity Number (CIN): U40109RJ2000SGC016485]
 Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005



Rajkaj Ref No. : 3989648

Reason: Approved
Date: 2023.06.07 17:55:47 IST
Engineer
Designation: Superintending
Digitally signed by Mukul Bhargava
Signature valid
RRVPNL, Jaipur
Superintending Engineer (SOLD)

Rajasthan.
31(A), 6th Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganeer Road, Jaipur-302019,
Copy forwarded to the M/s Barmer Power Transmission Service Limited (BPTSL),

(Mukul Bhargava)
Superintending Engineer (SOLD)
RRVPNL, Jaipur

This is for your kind information and further necessary action please.

99.995 %	Total transmission system availability
100.00 %	Availability of Power Transformers / ICTs
99.991 %	Availability of AC lines

M/s Barmer Power Transmission Service Limited (BPTSL) for the month May' 2023 are certified provisionally as under:-
Accordingly, the element wise availability & total transmission system availability of

On the aforesaid subject and reference it is to intimate that the element wise availability & total transmission system availability of M/s Barmer Power Transmission Service Limited (BPTSL) for the month May' 2023 has been checked on the basis of outage details and supporting documents submitted by licensee under reference and outage details received from concerned field officer.

Ref :- Letter No. BPTSL/SLDC/02062023/01 Dated 02.06.2023 of M/s BPTSL.

Sub:- Certification of Transmission System Availability of Barmer Power Transmission Service Limited (BPTSL) under RAJ/PPP-09, for the month May' 2023.

RRVPNL, Jaipur

The Superintending Engineer (Billing),

No. RVPN/SE (SOLD)/XEN-1/F. /D.

Dated:-

E-mail: se.sold@rvpn.co.in website: [www.http://energy.rajasthan.gov.in/rvpn](http://energy.rajasthan.gov.in/rvpn)

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)

SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403

Regd. Office: Vidyt Bhawan, Japath, Jyoti Nagar, Jaipur-302005

[Corporate Identity Number (CIN): U40109RJ2000SGC016485]

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

An ISO 9001:2015 Certified Company

RRVPNL





Rajkaj Ref No. : 4203638

Reason: Approved
Date: 2023.07.07 17:24:50 IST
Engineer
Designation: Superintending
Digitally signed by Mukul Bhargava
Supervising Engineer (SOLD)
RRV/NL, Jaipur

Copy forwarded to the M/s Barmer Power Transmission Service Limited (BPTSL),
31(A), 6th Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganeer Road, Jaipur-302019,
Rajasthan.

(Mukul Bhargava)
Superintending Engineer (SOLD)
RRV/NL, Jaipur

This is for your kind information and further necessary action please.

Availability of AC lines	100.00 %
Availability of Power Transformers / ICTs	100.00 %
Total transmission system availability	100.00 %

Accordingly, the element wise availability & total transmission system availability of
M/s Barmer Power Transmission Service Limited (BPTSL) for the month June 2023 are
certified provisionally as under:-

On the aforesaid subject and reference it is to intimate that the element wise
availability & total transmission system availability of M/s Barmer Power Transmission
Service Limited (BPTSL) for the month June 2023 has been checked on the basis of outage
details and supporting documents submitted by licensee under reference and outage details
received from concerned field officer.

Ref :- Letter No. BPTSL/SLDC/03072023/01 Dated 03.07.2023 of M/s BPTSL.

Sub:- Certification of Transmission System Availability of Barmer Power Transmission
Service Limited (BPTSL) under RAJ/PP-09, for the month June 2023.

The Superintending Engineer (Billing),
RVN/NL, Jaipur

No. RVP/SE (SOLD)/XEN-1/F. /D. Dated:-

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)
SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403
E-mail: se.sold@rvpn.co.in website: www.http://energy.rajasthan.gov.in/rvpl

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED
[Corporate Identity Number (CIN): U40109RJ2000SGC016485]
Regd. Office: Vidyt Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

An ISO 9001:2015
Certified Company

RVPN





Ref No. 4460998

Reason: Approved
Date: 2023.08.02 18:06:30 IST
Engineer
Designation: Superintending
Digitally signed by Mukul Bhargava
Signature valid
RRVPNL, Jaipur
Superintending Engineer (SOLD)

Copy forwarded to the M/s Barmer Power Transmission Service Limited (BPTSL),
31(A), 6th Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganeer Road, Jaipur-302019,
Rajasthan.

(Mukul Bhargava)
Superintending Engineer (SOLD)
RRVPNL, Jaipur

This is for your kind information and further necessary action please.

Availability of AC lines	100.00 %
Availability of Power Transformers / ICTS	100.00 %
Total transmission system availability	100.00 %

Accordingly, the element wise availability & total transmission system availability of
M/s Barmer Power Transmission Service Limited (BPTSL) for the month July' 2023 are
certified provisionally as under:-
On the aforesaid subject and reference it is to intimate that the element wise
availability & total transmission system availability of M/s Barmer Power Transmission
Service Limited (BPTSL) for the month July' 2023 has been checked on the basis of outage
details and supporting documents submitted by licensee under reference and outage details
received from concerned field officer.

Sub:- Certification of Transmission System Availability of Barmer Power Transmission
Service Limited (BPTSL) under RAJ/PP-09, for the month July' 2023.
Ref :- Letter No. BPTSL/SLDC/02082023/01 Dated 02.08.2023 of M/s BPTSL.

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D.
The Superintending Engineer (Billing),
RUVNL, Jaipur
Dated:-

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)
SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403
E-mail: se.sold@rvpn.co.in Website: www.http://energy.rajasthan.gov.in/rvpnl



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED
[Corporate Identity Number (CIN): U40109RJ2000SGC016485]
Regd. Office: Vidyt Bhawan, Janpath, Jyoti Nagar, Jaipur-302005



Rajkaj Ref No. : 465829

Superintending Engineer (SOLD)
RRVFNL, Jaipur
Signature valid
Digitally signed by Mukul Bhargava
Designation, Superintending
Engineer
Date: 2023.09.08:34:06 IST
Reason: Approved

(Mukul Bhargava)
Superintending Engineer (SOLD)
RRVFNL, Jaipur
Copy forwarded to the M/s Barmer Power Transmission Service Limited (BPTSL),
31(A), 6th Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganeer Road, Jaipur-302019,
Rajasthan.

This is for your kind information and further necessary action please.

100.00 %	Availability of AC lines
100.00 %	Availability of Power Transformers / ICTs
100.00 %	Total transmission system availability

Accordingly, the element wise availability & total transmission system availability of
M/s Barmer Power Transmission Service Limited (BPTSL) for the month August 2023 are
certified provisionally as under:-
On the aforesaid subject and reference it is to intimate that the element wise
availability & total transmission system availability of M/s Barmer Power Transmission
Service Limited (BPTSL) for the month August 2023 has been checked on the basis of
outage details and supporting documents submitted by licensee under reference and outage
details received from concerned field officer.

Ref :- Letter No. BPTSL/SLDC/02092023/01 Dated 02.09.2023 of M/s BPTSL.

Sub:- Certification of Transmission System Availability of Barmer Power Transmission
Service Limited (BPTSL) under RAJ/PP-09, for the month August 2023.

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D.
Dated:-
The Superintending Engineer (Billing),
RUVNL, Jaipur

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)
SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2250403
E-mail: se.sold@rvpn.co.in website: www.http://energy.rajasthan.gov.in/rvpnl

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED
[Corporate Identity Number (CIN): U40109RJ2000SGC016485]
Regd. Office: Vidyut Bhawan, Japath, Jyoti Nagar, Jaipur-302005

An ISO 9001:2015
Certified Company

RRVFN





Rajkaj Ref No. : 4854879

Supertending Engineer (SOLD)
RRVPNL, Jaipur
Signature valid
Digitally signed by Mukul Bhargava
Designation: Supertending
Engineer
Date: 2023.10.03 18:27:00 IST
Reason: Approved

Copy forwarded to the M/s Barmer Power Transmission Service Limited (BPTSL),
31(A), 6th Floor, Plot No. 5, Swej Farm, Mahima Trinity, New Sanganeer Road, Jaipur-302019,
Rajasthan.

(Mukul Bhargava)
Supertending Engineer (SOLD)
RRVPNL, Jaipur

This is for your kind information and further necessary action please.

Availability of AC lines	99.993 %
Availability of Power Transformers / ICTs	100.00 %
Total transmission system availability	99.996 %

Accordingly, the element wise availability & total transmission system availability of
M/s Barmer Power Transmission Service Limited (BPTSL) for the month September 2023
are certified provisionally as under:-
On the aforesaid subject and reference it is to intimate that the element wise
availability & total transmission system availability of M/s Barmer Power Transmission
Service Limited (BPTSL) for the month September 2023 has been checked on the basis of
outage details and supporting documents submitted by licensee under reference and outage
details received from concerned field officer.

Sub:- Certification of Transmission System Availability of Barmer Power Transmission
Service Limited (BPTSL) under RAJ/PP-09, for the month September 2023.
Ref :- Letter No. BPTSL/SLDC/03102023/01 Dated 03.10.2023 of M/s BPTSL.

No. RVPN/SE (SOLD)/XEN-1(SOLD)/F. /D.
The Supertending Engineer (Billing),
RUVNL, Jaipur
Dated:-

OFFICE OF THE SUPERINTENDING ENGINEER (SOLD)
SLDC BUILDING, HEERAPURA, Jaipur-302024 Tel. No. 0141-2260403
E-mail: se.sold@rvpn.co.in website: www.http://energy.rajasthan.gov.in/rvprnl

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED
(Corporate Identity Number (CIN): U40109RJ2000SGC016485)
Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

RRVPN
An ISO 9001:2015
Certified Company

